



Master data		
Customer no.	Report no.	20230125140955
Customer name	Company	Gossen Metrawatt Südwestpark 15 90449 Nürnberg
Representative	Inspector	Wilfred van den berg

Testdevice		
Testdevice ident	406024880	Designation
Manufacturer		Serial number
Туре		Notice
Cost center		Department

Reporting	
Next reporting	12/30/2023
Utilized measuring	SecuTest S4 BL5710890004

Classifications			
Name	Value		
Protection class	Class II		
Connection	test socket		
Meas. Mode	Passive		

Measured Values		12/30/2022 10:13 AM		<
Measurement step name	Measurement name	Measured value	Limit value	Passed
Visuele insp.	Sight check			4
RISO SK II	RINS	>300 MΩ	≥2.00 MΩ	4
IT Alt.	IT≃	21 μΑ	≤500 μA	₽
Functietest	Р	189 W		*
Functietest	S	189 VA		*
Functietest	PF	1.00		*
Functietest	I	0.83 A		*
Functietest	U	228.1 V		*
Functietest	f	50.0 Hz		*

Signature					
Representa	itive		Inspector		
	1/25/2023		Nürnberg	1/25/2023	
Location	Date	Signature	Location	Date	Signature

Report no. 20230125140955 Page 1