

Master data

Customer no.	Report no.	20240226140220
Customer name	Company	Gossen Metrawatt Südwestpark 15 90449 Nürnberg
Representative	Inspector	Wilfred van den berg

Testdevice

Testdevice ident	404789823	Designation
Manufacturer		Serial number
Type		Notice
Cost center		Department











Reporting

Next reporting	1/5/2025
Utilized measuring	SecuTest S4 BL5710890004

Classifications

Name	Value
Protection class	Class II
Connection	test socket
Meas. Mode	Passive

Measured Values

		1/5/2024 1:30 PM		
Measurement step name	Measurement name	Measured value	Limit value	Passed
Visuele insp.	Sight check			
RISO SK II	RINS	>300 MΩ	≥2.00 MΩ	
IT Alt.	IT≈	2 μA	≤500 μA	
Functietest	P	105 W		
Functietest	S	150 VA		
Functietest	PF	0.70		
Functietest	I	0.67 A		
Functietest	U	223.6 V		
Functietest	f	50.0 Hz		

Signature

Representative			Inspector		
2/26/2024			Nürnberg 2/26/2024		
Location	Date	Signature	Location	Date	Signature