



Master data		
Customer no.	Report no.	20240226135014
Customer name	Company	Gossen Metrawatt Südwestpark 15 90449 Nürnberg
Representative	Inspector	Wilfred van den berg

Testdevice		
Testdevice ident	21252122	Designation
Manufacturer		Serial number
Туре		Notice
Cost center		Department

Reporting	
Next reporting	1/5/2025
Utilized measuring	SecuTest S4 BL5710890004

Classifications			
Name	Value		
Protection class	Class II		
Connection	test socket		
Meas. Mode	Passive		

Measured Values		1/5/2024 11:40 AM		<
Measurement step name	Measurement name	Measured value	Limit value	Passed
Visuele insp.	Sight check			*
RISO SK II	RINS	>300 MΩ	≥2.00 MΩ	<
IT Alt.	IT≃	2 μΑ	≤500 μA	♦
Functietest	Р	24 W		*
Functietest	S	41 VA		₽
Functietest	PF	0.57		*
Functietest	I	0.19 A		*
Functietest	U	223.6 V		*
Functietest	f	50.0 Hz		⋄

Signature					
Representa	ative		Inspector		
	2/26/2024		Nürnberg	2/26/2024	
Location	Date	Signature	Location	Date	Signature
Donart no		20240226125014			Daga 1

Report no. 20240226135014 Page 1