

**Master data**

Customer no.	Report no.	20240103133450
Customer name	Company	Gossen Metrawatt Südwestpark 15 90449 Nürnberg
Representative	Inspector	Wilfred van den berg

**Testdevice**

Testdevice ident	406024890	Designation
Manufacturer		Serial number
Type		Notice
Cost center		Department











**Reporting**

Next reporting	12/21/2024
Utilized measuring	SecuTest S4 BL5710890004

**Classifications**

Name	Value
Protection class	Class II
Connection	test socket
Meas. Mode	Passive

**Measured Values**

		12/21/2023 12:06 PM		
Measurement step name	Measurement name	Measured value	Limit value	Passed
Visuele insp.	Sight check			
RISO SK II	RINS	>300 MΩ	≥2.00 MΩ	
IT Alt.	IT≈	2 μA	≤500 μA	
Functietest	P	65 W		
Functietest	S	66 VA		
Functietest	PF	0.98		
Functietest	I	0.28 A		
Functietest	U	233.8 V		
Functietest	f	50.0 Hz		

**Signature**

Representative			Inspector		
1/3/2024			Nürnberg 1/3/2024		
Location	Date	Signature	Location	Date	Signature