



| Master data | | |
|----------------|------------|--|
| Customer no. | Report no. | 20240103131845 |
| Customer name | Company | Gossen Metrawatt Südwestpark 15 90449 Nürnberg |
| Representative | Inspector | Wilfred van den berg |

| Testdevice | | |
|------------------|-----------|---------------|
| Testdevice ident | 410728401 | Designation |
| Manufacturer | | Serial number |
| Туре | | Notice |
| Cost center | | Department |

Reporting12/21/2024Utilized measuringSecuTest S4 BL5710890004

| Classifications | | | | |
|------------------|-------------|--|--|--|
| Name | Value | | | |
| Protection class | Class II | | | |
| Connection | test socket | | | |
| Meas. Mode | Passive | | | |

| Measured Values | | 12/21/2023 10:22 AM | | < |
|-----------------------|------------------|---------------------|-------------|----------|
| Measurement step name | Measurement name | Measured value | Limit value | Passed |
| Visuele insp. | Sight check | | | 4 |
| RISO SK II | RINS | >300 MΩ | ≥2.00 MΩ | 4 |
| IT Alt. | IT≃ | 7 μΑ | ≤500 μA | ₽ |
| Functietest | Р | 1 W | | * |
| Functietest | S | 6 VA | | * |
| Functietest | PF | 0.16 | | * |
| Functietest | I | 0.03 A | | * |
| Functietest | U | 233.8 V | | * |
| Functietest | f | 50.0 Hz | | * |

| Signature | | | | | |
|------------|----------|-----------|-----------|----------|-----------|
| Representa | itive | | Inspector | | |
| | 1/3/2024 | | Nürnberg | 1/3/2024 | |
| Location | Date | Signature | Location | Date | Signature |

Report no. 20240103131845 Page 1