











Master data		
Customer no.	Report no.	20240226141806
Customer name	Company	Gossen Metrawatt Südwestpark 15 90449 Nürnberg
Representative	Inspector	Wilfred van den berg

Testdevice		
Testdevice ident	11572644	Designation
Manufacturer		Serial number
Type		Notice
Cost center		Department

Reporting	
Next reporting	12/23/2024
Utilized measuring	SecuTest S4 BL5710890004

Classifications	
Name	Value
Protection class	Class II
Connection	test socket
Meas. Mode	Passive

Measured Values		12/23/2023 11:14 AM		
Measurement step name	Measurement name	Measured value	Limit value	Passed
Visuele insp.	Sight check			
RISO SK II	RINS	>300 MΩ	≥2.00 MΩ	
IT Alt.	IT≈	2 μA	≤500 μA	
Functietest	P	184 W		
Functietest	S	325 VA		
Functietest	PF	0.57		
Functietest	I	1.54 A		
Functietest	U	211.0 V		
Functietest	f	50.0 Hz		

Signature					
Representative			Inspector		
2/26/2024			Nürnberg 2/26/2024		
<hr/>			<hr/>		
Location	Date	Signature	Location	Date	Signature