



ERCOT Grid Operations

ESR Integration Report : 09/28/2024

Current Daily Values:

Installed ESR Discharge Capacity*	8,893 MW
Total ESR Discharge Capacity**	10,044 MW
Installed ESR Charge Capacity+	9,973 MW
Total ESR Charge Capacity++	9,973 MW

Peak Load	66,880 MW
Peak Load Hour (HE)	17
ESR Discharge at Peak Load Hour	29 MW
ESR Charge at Peak Load Hour	205 MW
ESR Net Charge/Discharge at Peak Load Hour^	-177 MW

Max ESR Discharge Generation	3,265 MW
Max ESR Discharge Time	19:18
Penetration at Max ESR Discharge Time	5.29%

Max ESR Charge Load	2,310 MW
Max ESR Charge Time	09:09
Penetration at Max ESR Charge Time	4.80%

Max ESR Discharge Penetration	5.29%
Max ESR Discharge Penetration Time	19:18
ESR Discharge Generation at Max ESR Discharge Penetration Time	3,265 MW

Max ESR Charge Penetration	4.81%
Max ESR Charge Penetration Time	09:04
ESR Charge Load at Max ESR Charge Penetration Time	2,298 MW

* Sum of maximum capacity (i.e. seasonal net max. sustainable rating in RIOO) of all ESR generators modeled in ERCOT's network operations model and are commercially operable (estimated based on Commercial Operations Date in RIOO).

** Sum of maximum capacity (i.e. seasonal net max. sustainable rating in RIOO) of all ESR generators modeled in ERCOT's network operations model.

+ Sum of maximum capacity (i.e. maximum point of delivery total load in RIOO) of all ESR CLR's that are modeled in ERCOT's network operations model and are commercially operable (estimated based on Commercial Operations Date in RIOO).


++ Sum of maximum capacity (i.e. maximum point of delivery total load in RIOO) of all ESR CLR's that are modeled in ERCOT's network operations model.

^ ESR Net Charge/Discharge = Total Discharging from ESR generators - Total Charging from ESR CLR's. Positive represents Net Discharge; negative represents Net Charge.


Note that generation, generation record, and generator capacity values in following pages of this report are based on units modeled in ERCOT's network operations model.

Hourly Average Actual Load vs. Actual ESR Output


09/28/2024




Actual ESR Discharging Output as a Percentage of Total Installed ESR Discharge Capacity 09/28/2024



Actual ESR Charging Output as a Percentage of Total Installed ESR Charge Capacity 09/28/2024



Actual ESR Net Output as a Percentage of ERCOT Load 09/28/2024



ERCOT Load vs. Actual ESR Net Output
09/21/2024 - 09/28/2024

