



ERCOT Grid Operations

ESR Integration Report : 03/12/2025

Current Daily Values:

Installed ESR Discharge Capacity*	10,548 MW
Total ESR Discharge Capacity**	13,417 MW
Installed ESR Charge Capacity+	12,225 MW
Total ESR Charge Capacity++	13,321 MW

Peak Load	55,015 MW
Peak Load Hour (HE)	18
ESR Discharge at Peak Load Hour	348 MW
ESR Charge at Peak Load Hour	411 MW
ESR Net Charge/Discharge at Peak Load Hour^	-63 MW

Max ESR Discharge Generation	3,210 MW
Max ESR Discharge Time	20:00
Penetration at Max ESR Discharge Time	6.01%

Max ESR Charge Load	2,566 MW
Max ESR Charge Time	11:45
Penetration at Max ESR Charge Time	5.13%

Max ESR Discharge Penetration	6.28%
Max ESR Discharge Penetration Time	07:44
ESR Discharge Generation at Max ESR Discharge Penetration Time	2,850 MW

Max ESR Charge Penetration	5.79%
Max ESR Charge Penetration Time	01:20
ESR Charge Load at Max ESR Charge Penetration Time	2,470 MW

* Sum of maximum capacity (i.e. seasonal net max. sustainable rating in RIOO) of all ESR generators modeled in ERCOT's network operations model and are commercially operable (estimated based on Commercial Operations Date in RIOO).

** Sum of maximum capacity (i.e. seasonal net max. sustainable rating in RIOO) of all ESR generators modeled in ERCOT's network operations model.

+ Sum of maximum capacity (i.e. maximum point of delivery total load in RIOO) of all ESR CLR's that are modeled in ERCOT's network operations model and are commercially operable (estimated based on Commercial Operations Date in RIOO).


++ Sum of maximum capacity (i.e. maximum point of delivery total load in RIOO) of all ESR CLR's that are modeled in ERCOT's network operations model.

^ ESR Net Charge/Discharge = Total Discharging from ESR generators - Total Charging from ESR CLR's. Positive represents Net Discharge; negative represents Net Charge.


Note that generation, generation record, and generator capacity values in following pages of this report are based on units modeled in ERCOT's network operations model.

Hourly Average Actual Load vs. Actual ESR Output


03/12/2025




Actual ESR Discharging Output as a Percentage of Total Installed ESR Discharge Capacity 03/12/2025



Actual ESR Charging Output as a Percentage of Total Installed ESR Charge Capacity 03/12/2025



Actual ESR Net Output as a Percentage of ERCOT Load 03/12/2025



ERCOT Load vs. Actual ESR Net Output
03/05/2025 - 03/12/2025

