



## ERCOT Grid Operations

### ESR Integration Report : 07/02/2024

#### Current Daily Values:

Installed ESR Discharge Capacity*	8,025 MW
Total ESR Discharge Capacity**	9,048 MW
Installed ESR Charge Capacity+	8,993 MW
Total ESR Charge Capacity++	8,993 MW

Peak Load	81,108 MW
Peak Load Hour (HE)	17
ESR Discharge at Peak Load Hour	213 MW
ESR Charge at Peak Load Hour	206 MW
ESR Net Charge/Discharge at Peak Load Hour^	7 MW

Max ESR Discharge Generation	2,088 MW
Max ESR Discharge Time	19:24
Penetration at Max ESR Discharge Time	2.62%

Max ESR Charge Load	944 MW
Max ESR Charge Time	09:20
Penetration at Max ESR Charge Time	1.49%

Max ESR Discharge Penetration	2.64%
Max ESR Discharge Penetration Time	20:09
ESR Discharge Generation at Max ESR Discharge Penetration Time	2,032 MW

Max ESR Charge Penetration	1.53%
Max ESR Charge Penetration Time	08:36
ESR Charge Load at Max ESR Charge Penetration Time	917 MW

\* Sum of maximum capacity (i.e. seasonal net max. sustainable rating in RIOO) of all ESR generators modeled in ERCOT's network operations model and are commercially operable (estimated based on Commercial Operations Date in RIOO).

\*\* Sum of maximum capacity (i.e. seasonal net max. sustainable rating in RIOO) of all ESR generators modeled in ERCOT's network operations model.

+ Sum of maximum capacity (i.e. maximum point of delivery total load in RIOO) of all ESR CLRs that are modeled in ERCOT's network operations model and are commercially operable (estimated based on Commercial Operations Date in RIOO).


++ Sum of maximum capacity (i.e. maximum point of delivery total load in RIOO) of all ESR CLRs that are modeled in ERCOT's network operations model.

^ ESR Net Charge/Discharge = Total Discharging from ESR generators - Total Charging from ESR CLRs. Positive represents Net Discharge; negative represents Net Charge.


Note that generation, generation record, and generator capacity values in following pages of this report are based on units modeled in ERCOT's network operations model.

## Hourly Average Actual Load vs. Actual ESR Output

07/02/2024



## Actual ESR Discharging Output as a Percentage of Total Installed ESR Discharge Capacity 07/02/2024




## Actual ESR Charging Output as a Percentage of Total Installed ESR Charge Capacity 07/02/2024



## Actual ESR Net Output as a Percentage of ERCOT Load

07/02/2024



ERCOT Load vs. Actual ESR Net Output  
06/25/2024 - 07/02/2024

