

MATRIX SYSTEMS

5591 LEO PARK RD
WEST JORDAN, UT 84081
(801) 930-9492



Project Number:
Project Name: Clarifier
Drawing Number:

RSG-10005

Product ID: LP
Product Description: Load Cell Panel

Customer: Rebuild-It Services Group
Customer Job No.: 14784
Commission:
Manufacturing Date: 2022

Power Supply	120 Vac / 1Φ / 60 Hz	Env. Protection Rating	UL Type 4X
Max Current	5 A	Largest Motor	N/A
Nominal Current	1 A	Static Heat Load	N/A
SCCR	N/A	Duty Heat Load	N/A
Min Feeder Size	14 AWG	Weight	25 lb
Control Voltage	120 Vac / 1Φ / 60 Hz		

Created	2022-11-18	JSP
Last Modified	2022-11-18	JSP

REV	REVISION COMMENT	DATE	DESIGNER
A	Initial Release	2022-11-18	JSP

☐ APPROVED

☐ APPROVED W/ REVISIONS NOTED

☐ REJECTED, RESUBMIT REQUIRED

APPROVED BY (PRINT NAME)

SIGNATURE

POSITION

DATE

NOTE: APPROVAL SIGNATURE IS REQUIRED BEFORE PROCUREMENT, FABRICATION OR PRODUCTION WILL BEGIN. ANY COMMERCIAL IMPACT IN THE FORM OF CHANGES, REVISIONS, OR MODIFICATIONS MADE AFTER PRODUCTION STARTS MAY RESULT IN DELAYS OR ADDITIONAL COSTS.

NOTES:

Table of contents

Page	Page Description	Notes	Date	Edited by
1	Cover Page		2022-11-18	JSP
2	Table of Contents		2022-11-18	JSP
3	Bill of Materials: LP		2022-11-18	JSP
4	Technical Requirements		2022-11-18	JSP
5	Panel Layout		2022-11-18	JSP
6	Mounting Panel Layout		2022-11-18	JSP
7	Mounting Panel Layout - Duct & Din		2022-11-18	JSP
8	Precision Digital		2022-11-18	JSP

Bill of Materials: Load Cell Panel (LP)

Idx	Qty	Part Number	Part Description	Manufacturer	Supplier	Customer Supplied	Device Tag	Location	Remarks
1	1 ea	CP1212	Concept Panel, fits 12.00x12.00, White, Steel	nVent Hoffman	RWE	☐	7	Load Cell Panel	
2	1 ea	CSD12126WSS	Concept Window-Door 1/4-Turn Latch Type 4x, 12x12x6, 304 SS	nVent Hoffman	RWE	☐	4	Load Cell Panel	
3	1 ea	LC-001	Standoff, Steel, Precision Digital Mount	Matrix Systems	MTX	☐	8	Load Cell Panel	
4	1 ea	PD6100-6R7	PD6100 ProVu Strain Gauge, Load Cell & mV Digital Panel Meter	Precision Digital Corporation	PDC	☐	DV101	Load Cell Panel	
5	2 ea	0800886	End clamp, width: 9.5 mm, color: gray	Phoenix Contact	RWE	☐	.1;2	Load Cell Panel	
6	1 ft	0801733	DIN rail, material: steel galvanized and passivated with a thick layer, perforated, height 7.5 mm, width 35 mm, length: 2000 mm	Phoenix Contact	RWE	☐	U320	Load Cell Panel	
7	1 ea	0916607	Thermomagnetic circuit breaker, 1-pos., for DIN rail mounting	Phoenix Contact	RWE	☐	CB402	Load Cell Panel	
8	3 ea	3022218+1004348	Quick mounting end clamp for NS 35/7,5 DIN rail or NS 35/15 DIN rail, with marking option, width: 9.5 mm, color: gray	Phoenix Contact	RWE	☐	TB1...TB3	Load Cell Panel	
9	21 ea	3044102	Feed-through terminal block, Connection method: Screw connection, Cross section: 0.14 mm² - 6 mm², AWG: 26 - 10, Width: 6.2 mm, Color: gray, Mounting type: NS 35/7,5, NS 35/15	Phoenix Contact	RWE	☐	TB1...TB3	Load Cell Panel	
10	2 ea	3044128	Ground modular terminal block, Connection method: Screw connection, Cross section: 0.14 mm² - 6 mm², AWG: 26 - 10, Width: 6.2 mm, Color: green-yellow, Mounting type: NS 35/7,5, NS 35/15	Phoenix Contact	RWE	☐	TB1;TB2	Load Cell Panel	
11	3 ea	3047028	End cover, length: 47 mm, width: 2.2 mm, height: 39.8 mm, color: gray	Phoenix Contact	RWE	☐	TB1...TB3	Load Cell Panel	

IDX	PAGE MODIFICATION	DATE	DESIGNER	PROJECT REV A	PROJECT NO. 52201566	PAGE	Bill of Materials: LP			MATRIX S Y S T E M S 5591 LEO PARK RD WEST JORDAN, UT 84081 SIZE B DWG NO. 52201566-02 SHEET 3 / 8
				DESIGNER JSP	CUST JOB ID 14784	TITLE	Clarifier Load Cell Panel			
				APPD BY	INSTALLATION					
				DATE 2022-11-18	PANEL ID					


OUTPUT CONTROL SYMBOLS

SYMBOL	DESCRIPTION
	RELAY COIL (CR) CONTACTOR (M)
	SOLENOID (SOL)
	PILOT LIGHT X = COLOR (LT) or (PBL)
	ALARM HORN (AH)
	HEATING ELEMENT (HTR)

INPUT CONTROL SYMBOLS

NORMALLY OPEN	NORMALLY CLOSED	DESCRIPTION
		PUSHBUTTON (PB) or (PBL)
		SELECTOR SWITCH (SS) or (SSL)
		MUSHROOM PUSHBUTTON (PB) or (PBL)
		LIMIT SWITCH (LS)
		AUXILIARY CONTACT

POWER DIST. SYMBOLS


SYMBOL	DESCRIPTION
	DISCONNECT SWITCH (DS)
	CIRCUIT BREAKER (CB)
	FUSE (FU)
	MOTOR OVERLOAD (OL)
	MOTOR STARTER (M)
	3-PHASE MOTOR (MTR)

WIRING COLORS


Ungrounded Power Circuits	Black	(BLK)
Grounded AC Power Circuits	White	(WHT)
Protective wire	Green	(GRN)
Ungrounded AC Control Circuits	Red	(RED)
Grounded AC Control Circuits	White	(WHT)
Ungrounded DC Control Circuits	Blue	(BLU)
Grounded DC Control Circuits	White/Blue	(W/B)
External Voltage Source	Orange	(ORG)
Excepted Circuits	Orange	(ORG)

Symbols in accordance with UL 508A


IDX	PAGE MODIFICATION	DATE	DESIGNER	PROJECT REV	PROJECT NO.	PAGE	5591 LEO PARK RD WEST JORDAN, UT 84081		
				DESIGNER	CUST JOB ID	TITLE			
				APPD BY	INSTALLATION				
				DATE	PANEL ID				
				A	52201566	Technical Requirements			
				JSP	14784	Clarifier			
						Load Cell Panel			
				2022-11-18			SIZE	DWG NO.	SHEET
							B	52201566-02	4 / 8




Top



Front



Right




IDX	PAGE MODIFICATION	DATE	DESIGNER	PROJECT REV	PROJECT NO.	PAGE
				A	52201566	Panel Layout
				DESIGNER	CUST JOB ID	TITLE
				JSP	14784	Clarifier
				APPD BY	INSTALLATION	Load Cell Panel
				DATE	PANEL ID	
				2022-11-18		



MATRIX
SYSTEMS


5591 LEO PARK RD
WEST JORDAN, UT 84081

SIZE	DWG NO.	SHEET
B	52201566-02	5 / 8



Mouting Panel


IDX	PAGE MODIFICATION	DATE	DESIGNER	PROJECT REV	PROJECT NO.	PAGE	MATRIX SYSTEMS 5591 LEO PARK RD WEST JORDAN, UT 84081		
				A	52201566	Mounting Panel Layout			
				DESIGNER JSP	CUST JOB ID 14784	TITLE Clarifier Load Cell Panel			
				APPD BY	INSTALLATION				
				DATE 2022-11-18	PANEL ID		SIZE	DWG NO.	SHEET
							B	52201566-02	6 / 8



Duct & Din Layout

IDX	PAGE MODIFICATION	DATE	DESIGNER	PROJECT REV A	PROJECT NO. 52201566	PAGE	Mounting Panel Layout - Duct & Din			 MATRIX SYSTEMS 5591 LEO PARK RD WEST JORDAN, UT 84081
				DESIGNER JSP	CUST JOB ID 14784	TITLE	Clarifier Load Cell Panel			
				APPD BY	INSTALLATION					
				DATE 2022-11-18	PANEL ID					
							SIZE B	DWG NO. 52201566-02	SHEET 7 / 8	

101
102
103
104
105
106
107
108
109
110
111
112
113
114
115
116
117
118
119
120
121
122
123
124
125
126
127
128
129
130
131
132
133
134
135



IDX	PAGE MODIFICATION	DATE	DESIGNER	PROJECT REV A	PROJECT NO. 52201566	PAGE	Precision Digital		
				DESIGNER JSP	CUST JOB ID 14784	TITLE	MATRIX SYSTEMS 5591 LEO PARK RD WEST JORDAN, UT 84081 SIZE B DWG NO. 52201566-02 SHEET 8 / 8		
				APPD BY	INSTALLATION				
				DATE 2022-11-18	PANEL ID				
							Clarifier Load Cell Panel		