

ELECTRICAL DRAWING INDEX		
DWG #	SHEET DESCRIPTION	
RSW1673-121 SHT1	TITLE SHEET AND CONSTRUCTION NOTES	
RSW1673-121 SHT2	SUB-PANEL LAYOUT AND BILL OF MATERIALS	
RSW1673-121 SHT3	WIRING SCHEMATICS	

CONTROL PANEL SPECIFICATIONS

- COMPONENTS SPECIFIC**
 - ENCLOSURE TO BE NEMA 4X CONSTRUCTION.
 - ATTACH NAMEPLATES WITH MANUFACTURER'S RECOMMENDED ADHESIVE TO MAINTAIN NEMA STANDARD OF ENCLOSURE
 - CONTROL PANEL SHALL BE LABELED WITH SERIALIZED UL LABEL
 - PANEL WILL BE LABELED WITH IDENTIFICATION PLATE AS NOTED ON ENCLOSURE DRAWING.
 - ALL RELAY CONTACTS ARE RATED AT 10 AMPS UNLESS OTHERWISE NOTED.
 - COMPONENT IMAGES MAY NOT ACCURATELY REPRESENT THE ACTUAL DEVICE IN SOME INSTANCES. DIMENSIONS OF DEVICES, HOWEVER, WILL BE ACCURATE FOR PURPOSES OF LAYOUT AND SPACING.
 - SUBSTITUTIONS FOR COMPONENTS MAY BE PERMITTED UPON APPROVAL BY OVIVO ENGINEERS.
- WIRE SIZING & TYPE**

WIRE SIZING SHALL BE NO LESS THAN AS FOLLOWS (UNLESS OTHERWISE NOTED):
120 1 PHASE - 16 AWG TYPE: MTW
- WIRE COLOR**

WIRE COLOR SHALL BE AS FOLLOWS:
CONTROL (120 VAC)
RED - LOAD WIRES FOR ALL LOCAL CONTROL CIRCUITS
WHITE - NEUTRAL FOR ALL LOCAL CONTROL CIRCUITS
YELLOW - FOREIGN POWER IN PANEL
- CONNECTIONS**
 - ALL CONNECTIONS SHALL BE POINT TO POINT WITHOUT SPLICES. EXCEPTIONS APPLY TO SOLENOIDS AND MOTORS AND FACTORY WIRED COMPONENTS.
 - ALL CONDUCTORS MUST BE MARKED WITH MACHINE PRINTED TAGS AT EACH TERMINATION. MARKERS SHALL BE OF HEAT SHRINK TYPE.
- DOCUMENTATION**
 - FABRICATOR SHALL PROVIDE ONE COPY OF ALL DOCUMENTS SUPPLIED WITH THE COMPONENTS SUPPLIED BY THE FABRICATOR. THIS INFORMATION INCLUDES BUT IS NOT LIMITED TO MANUFACTURERS SPECIFICATIONS, INSTALLATION MANUALS AND OPERATION MANUALS.
 - ANY OVIVO APPROVED CHANGES OR MARK-UPS TO THE SCHEMATICS, PANEL LAYOUTS AND ANY OTHER PERTAINING DOCUMENTS SHALL BE MAINTAINED AND DELIVERED TO OVIVO AT ACCEPTANCE OF THE PANEL.
- TESTING**
 - OVIVO ENGINEERS OR OVIVO APPROVED FABRICATOR, WILL PERFORM A POINT TO POINT CONTINUITY TEST ON THE PANEL.
 - WHEN APPLICABLE, THE FABRICATOR WILL ALSO PROVIDE POWER TO THE 120VAC CIRCUITS FOR VERIFICATION AND TESTING. FABRICATOR SHALL ALLOW A MINIMUM OF 1 HOUR OF ACCESS TO THE CONTROL PANEL BY AN OVIVO ENGINEER FOR THIS AND PREVIOUSLY STATED TEST.

6.50" [165.10mm]	
HOLLYWOOD WWTP, FL DETRITOR CONTROL PANEL	
SUPPLY VOLTAGE:	120 VOLTS AC, 1 PH, 60 Hz
DATE OF MANUF:	MM/DD/YYYY
DRAWING NUMBER:	RSW1673-121
MOTOR HP:	0.0
SERIAL NUMBER:	RSW0001673-01
PA:	1.125
SCALE:	10
OVIVO Worldwide Experts in Water Treatment	

OVIVO NAMEPLATE
ENGRAVE AS SHOWN

DRAWN BY	RN
CHECKED BY	JLC
DATE	05/16/2026
PROJECT	RSW0001673-01
REF	RSW1100-121
SIZE	D
SHEET	1 OF 3

HOLLYWOOD WWTP, FL
DETRITOR CONTROL PANEL

RSW1673-121

SHEET
1 OF 3
A
REVISION

INITIAL RELEASE
REVISION SUMMARY
S-027224
ECO
BY
JLC
CHECKED
05/19/2026
A
THIS DRAWING CONTAINS CONFIDENTIAL, PROPRIETARY INFORMATION OF OVIVO AND ITS AFFILIATES AND IS NOT TO BE DISCLOSED NOR TO BE USED EXCEPT FOR EVALUATING PROPOSALS OF OVIVO ON INSTALLING, OPERATING OR MAINTAINING OVIVO EQUIPMENT UNLESS OTHERWISE AUTHORIZED IN WRITING BY OVIVO. UNCONTROLLED COPY IS PRINTED.
© 2024 OVIVO. ALL RIGHTS RESERVED.

