Job Safety Training Outline

Built to align with DAFI 91-202 paragraph 14.1 requirements.

Unit: 436 Civil Engineering Squadron

Work Center: Power Production

Work Area / Office Symbol: CEOFP

Phone: 302-677-4857

Supervisor: Jared Latham / MSgt

Reviewer: Not entered

Review Date: 2026-11-09

Effective Date: 2026-11-09

Work Center Overview

The primary mission of the 436 CES Power Production shop is to install, remove, operate, maintain, and repair electrical power generating and control systems, and associated equipment including 41 RPIE generators and 6 EAID units located accross the installation. Additionally, Power Pro maintains 8 fire suppression pumps systems that protect aircraft fuel facilities servicing a fleet of C-5/17.

Work Area Hazard Analysis / JHA Notes

BE Survey Notes: Dover AFB high-risk workplace (20 personnel) maintaining roads and flightlines. Measured Noise (98.6 dBA) and Silica (Quartz/Total Respirable: ~0.28 mg/m3) exposures are significantly above OEL.
JHA Findings & Major Hazards: Hazardous noise from heavy equipment, pneumatic tools, and flightline operations; respirable crystalline silica during demolition/cutting operations; Methanol skin absorption during weekly vehicle disassembly.
Controls: Double hearing protection (plugs and muffs); 3M 7800S respirators; chemical splash goggles; mandatory administrative training (silica, respiratory protection, heat/cold stress, hearing conservation).
Special Restrictions: Fetal Protection Program requires pregnant personnel to report immediately to Public Health for workplace evaluations, restriction recommendations (AF Form 422), and briefings.
Shop supervisors not requiring exams have a 0.00 dBA Noise E


Required Training Topics

Workplace HazardsPersonal Protective EquipmentEmergency Action and Fire PreventionReporting Unsafe Equipment, Conditions, or ProceduresMishap, Occupational Injury, and Illness ReportingCA-10 and LS-201DAF Traffic Safety ProgramDAFVA 91-209 Location and ContentDAFSMS Responsibilities

- **Workplace hazards:** Describe crushing, burn, chemical, ladder, weather, flight line, and noise hazards specific to the work center, plus the technical orders, JHAs, and instructions workers must follow.
- **Personal protective equipment:** Train employees on required PPE, including donning, doffing, cleaning, maintenance, storage, disposal, and reporting contact-lens or medical issues that could affect wear.
- **Emergency action and fire prevention:** Cover alarms, AEDs, extinguishers, evacuation routes, shelter locations, and response procedures tied to the work center.
- **Reporting unsafe conditions:** Instruct personnel to report unsafe equipment, conditions, procedures, and injuries without fear of reprisal, including use of DAF Form 457 and applicable reporting channels.
- **Mishap / injury / illness reporting:** Explain on-duty and off-duty reporting requirements, medical treatment procedures, and emergency response contacts.
- **Traffic safety:** Brief seat belt, speed limit, spotter, electronic device, and motorcycle safety requirements applicable to the work center.
- **DAFVA 91-209 and DAFSMS:** Review the location of DAFVA 91-209 and how workers contribute to the unit safety management system.

Hierarchy of Controls


Apply these controls from most effective to least effective when reducing workplace hazards under DAFI 91-202 paragraph 14.1.2.1.4.



Use the highest level of control feasible first. PPE should protect workers only after elimination, substitution, engineering, and administrative controls have been considered.

Active Shooter Response

In the event of an active shooter, individuals should employ the **Avoid, Deny, Defend** response method. This strategy is adaptable to the specific situation and environment.



Avoid (Run): The first and preferred course of action is to evacuate the area if a safe route is available. Maintain awareness of your surroundings and have an escape route planned. Leave your belongings, evacuate regardless of whether others follow, and do not attempt to move wounded people. Once you have reached a safe location, call 911 and provide any information you have.


Deny (Hide): If you cannot evacuate, your next priority is to deny the attacker access to your location. This involves more than just hiding; it means securing your position. Lock and blockade doors with heavy furniture, turn off lights, silence your phone, and remain out of the shooter's view. Remember that concealment only hides you, while cover can offer protection from bullets.

Defend (Fight): As a last resort, when your life is in immediate danger, you must be prepared to defend yourself. Act aggressively, improvise weapons from your surroundings, and commit fully to your actions. Taking action may be risky, but it could be your best or only chance for survival.

When law enforcement arrives: Remain calm, follow all instructions, keep your hands visible with fingers spread, and be prepared to provide information about the shooter’s location, number, and description.

DAFSMS Framework

DAFSMS uses four pillars and the DAFSMS framework to structure the mishap prevention program through continuous improvement and the Plan-Do-Check-Act model.



Policy and Leadership

Safety policy provides the structure for a proactive mishap prevention program. Active leadership involvement at every level is critical to implementation and sustained execution.

Risk Management

Integrate risk management into all safety-related activities so hazards are identified early, controls are implemented, and the safety culture stays proactive.

Assurance

Use evaluations, monitoring, and review processes to measure conformance to standards and drive continuous improvement across the mishap prevention program.

Promotion, Education, and Training

Provide safety awareness, embed ongoing training, implement effective controls, and keep airmen and guardians actively engaged in mishap prevention.

Department of the Air Force SMS Framework

Policy and Leadership

- Leadership planning, organization, direction, and control

- Management roles, responsibilities, and relationships
- Procedures and controls that are developed, documented, maintained, and monitored
- Safety and quality balance, integration, and goal setting

Risk Management

- Hazard identification through mission/task analysis and hazard lists
- Hazard assessment using exposure, probability, severity, and risk level
- Control options, effects, prioritization, selection, and decisions
- Implementation, communication, accountability, support, supervision, and feedback

Assurance

- Performance requirements, expectations, and control effectiveness
- Continuous monitoring, self-inspections, internal and external inspections
- Mishap and event investigation, reporting, metrics, and improvement opportunities
- Change management and continuous improvement actions

Promotion, Education, and Training

- Culture built on informed, flexible, learning, just, and reporting behaviors
- Competency through training and education
- Awareness through internal communication, external communication, and information access

Job Specific Training Items

The following modules apply to this work center and should be reviewed with trainees before task performance.

Hazardous Energy ControlHazard CommunicationHearing ConservationCPR TrainingFlight Line Driving

- **Hazardous Energy Control:** Document initial and refresher training when job assignments, machines, processes, or energy control procedures change, or when inspections show employee knowledge gaps. Train authorized employees to recognize hazardous energy sources, the type and magnitude of energy present, and the methods and means for isolation and control. Train affected employees on the purpose and use of lockout/tagout procedures, and instruct all other employees on the prohibition against restarting locked or tagged equipment. DAFMAN 91-203 - Air Force Occupational Safety, Fire and Health Standards, Chapter 21; 29 CFR 1910.147 - The control of hazardous energy (lockout/tagout)
- **Hazard Communication:** Provide HazCom training upon initial assignment, whenever a new chemical hazard is introduced, and when new tasks expose workers to different hazardous materials. Ensure workers know how to access local SDS information and labeling guidance. Train personnel on hazardous chemicals in their work area, labeling systems, safety data sheets, and the measures they can take to protect themselves during normal operations and foreseeable emergencies. DAFI 90-821; 29 CFR 1910.1200 - Hazard Communication

- **Hearing Conservation:** Ensure workers enrolled in hearing conservation understand noise hazard areas, double-hearing protection requirements, and local follow-up actions tied to occupational health evaluations. Train noise-exposed employees annually on the effects of noise, the purpose of hearing protectors, the advantages and disadvantages of various protectors, and the purpose of audiometric testing. DAFI 48-127; 29 CFR 1910.95 - Occupational noise exposure
- **CPR Training:** Ensure designated responders maintain current certification and understand location and use of local AED assets under the unit mishap prevention program. Provide CPR and AED training before assignment where required, and refresh qualification before expiration. DAFMAN 91-203 - Air Force Occupational Safety, Fire and Health Standards, Chapter 1
- **Flight Line Driving:** Use installation or unit-approved training and certification for airfield/fight line operations, to include local speed, spotter, and no-lone-zone requirements. Provide local flight line driving rules, markings, vehicle lighting requirements, restricted areas, and aircraft hazard awareness before granting driving privileges. DAFMAN 91-203 - Air Force Occupational Safety, Fire and Health Standards, Chapter 24

References

DAFMAN 91-203 - Air Force Occupational Safety, Fire and Health Standards AF Consolidated Occupational Safety Standard
AFI 91-202 The US AF Mishap Prevention Program
DAFI 91-204 Safety Investigations and Reports
AFI 91-207 The US Air Force Traffic Safety Program
AFMAN 32-1062 Electrical Systems, Power Plants, and Generators
AFMAN 32-1065 Grounding & Electrical Systems

Required Documents

- CA-10
  What a Federal Employee Should Do When Injured at Work. Use this as the workplace reference for employee injury reporting and follow-up actions.
- DAF Form 457
  Hazard Report. Use this form to identify, document, and elevate unsafe conditions, equipment, or procedures in the workplace.
- DAFVA 91-209 **UNITS MUST FILL OUT THEIR OWN LOCATION POSTED**
  Department of the Air Force Occupational Safety and Health Program visual aid. Keep this available so personnel know the core safety rights, responsibilities, and reporting expectations.
  Location Posted: Safety Bulletin Board
- LS-201
  Notice of Employee's Injury or Death (Non-Appropriated Funds). Use this when applicable for NAF employee injury or death reporting.

Emergency Information

- **Emergency Numbers:** On-Base Emergencies (Fire / Police / Medical): 911 (or 302-677-3333 from a cell phone to reach base dispatch)
  Dover AFB Command Post: 302-677-4201
  Bioenvironmental Engineering (BE) 302-677-2605 (or via Base Operator at 302-677-3000)
  Public Health Flight (Fetal Protection & Medical Exams): 302-730-4633 (Primary Appointment & Clinic Routing)
  436th Security Forces Squadron (SFS): 302-677-6664
  Military Health System Nurse Advice Line 1-800-TRICARE (874-2273)
- **Medical Facility / Treatment:** Ambulance & Emergency Response (Life, Limb, or Eyesight)

Immediately Call: Dial 911 (or 302-677-3333 if calling from a cellular device on base)
On-Base Response: Emergency medical dispatch coordinates through the Dover AFB Emergency Communication Center. On base, emergency medical response is provided 24/7 by the Ambulance Response Team (ART) (436th Medical Group / Civil Engineer Squadron Fire Station) in coordination with local Kent County/City of Dover EMS.

Actions On Scene:
State your exact building number (e.g., Bldg 626 / Power Production Shop), specific shop area/bay, and nature of injury.
Direct someone to flag down the emergency vehicle at the hangar/bay apron or street entrance.
For chemical contamination (e.g., methanol, solvent splashes, silica in eyes), begin immediate flushing at the eyewash station/drench shower and inform dispatch of the chemical involved.

Hospital & Emergency Room (Off-Base)

The 436th Medical Group Clinic on base does NOT have an Emergency Room. For severe trauma, life-threatening injuries, or after-hours emergencies requiring hospital care:

Primary Designated Emergency Room:
Bayhealth Hospital, Kent Campus (Kent General)
Address: 640 S. State St., Dover, DE 19901
Phone: (302) 674-4700
Reporting Requirement: If an active duty member is admitted to or treated at a civilian emergency department, notify the Primary Care Manager (PCM) / Flight Medicine and the workplace supervisor within 24 hours to ensure authorization and documentation.

Outpatient Clinic Procedures (436th Medical Group)
Location: Building 300, Tuskegee Blvd, Dover AFB
Routine & Occupational Care:
Appointment Line: Call (302) 730-4633
Occupational Health / Bioenvironmental / Public Health: Coordinates annual medical surveillance, audiograms, respirator clearances, and fetal protection program restrictions

Non-Emergency After-Hours:
Call the MHS Nurse Advice Line at 1-800-TRICARE (874-2273) prior to seeking off-base urgent care to avoid unauthorized medical billing

- **Evacuation / Muster Point:** Primary location: Rock climbing wall next to baseball field
  Secondary location: Parking Lot in front of the landings club
- **Shelter in Place:** 1. Alert all personnel to move to the Shelter-in-Place (SIP) location. ROOM #3
  2. Turn HVAC system off. LOCATED: MAIN BREAK AREA, TO THE RIGHT OF ENTRANCE TO ROOM 3
  3. Open SIP Kit (if applicable), begin running checklist. (Highest Ranking individual should take the lead).
  4. Secure all SIP room doors, ensuring they are secured and locked.
  5. (Optional) Wet towels from SIP kit and place towels firmly under the doors.
  6. Seal off doors, ventilation systems and windows using pre-cut plastic and duct tape from SIP kit. Ensure tape is fully connected around all edges of pre-cut plastic.
  7. Take accountability using recall roster in your SIP kit.
  8. Call your Unit Control Center (UCC) to report your building number and accountability.
  9. WAIT….do not leave SIP room until given the “ALL CLEAR”.
- **Active Shooter Response Methods:** Inside the Immediate Incident Area

  AVOID
  • If an escape route is accessible, evacuate the immediate area. Leave your belongings behind.

• Evacuate even if others will not agree to follow you. Help others evacuate, if possible. Prevent others from entering the area.
• Call 911 when you are safe.
• Stay on the phone until the operator ends the call.
• Follow any law enforcement instructions.
• If in view of or approaching law enforcement personnel, keep your hands visible.
• Do not attempt to move wounded individuals.

DENY
• If evacuation is not possible, find a place to create a barricade between you and the active shooter.
• Barricade where you are less likely to be found by the active shooter, provide you protection, and not restrict your options for movement.
• If possible, lock the door and/or block the door with heavy furniture. Turn off any lights and cover windows.
• Remain quiet and silence any devices (e.g., a cell phone) that may give away your location.
• If safe to do so, call 911 (Stay on the phone until the operator ends the call).

DEFEND
• As a last resort, and only when your life is in imminent danger, attempt to disrupt and/or incapacitate the shooter.
• Personnel should use whatever means possible to overpower the subject to save further lives.
• Use the minimum force necessary to subdue the shooter, however, deadly force is authorized when an individual. reasonably believes they or others in the area are in immediate danger of death or serious bodily harm.

Information to Provide to Law Enforcement or 911
• Number of active shooters, if more than one.
• Location of the shooter(s).
• Physical description of shooter(s).
• Time you observed the shooter(s).
• Number and type of weapons held by the shooter(s).
• Number of potential victims at the location.

When Law Enforcement Arrives
• Law enforcement’s purpose is to stop the active shooter as soon as possible.
• Officers will proceed directly to the area in which the last shots were heard and will not stop to help injured persons until the shooter is neutralized.
• Remain calm and follow instructions.
• Place any items in your hands on the ground.
• Immediately raise your hands and spread your fingers.
• Always keep hands visible.
• Do not impede law enforcement officers’ movements, such as holding on to them for safety.
• Provide any information that may assist them in countering the threat.
• Avoid pointing, screaming, and/or yelling.
• Do not stop to ask officers for help or directions when evacuating, just proceed in the direction they instruct you to go.
• Move quickly to the assembly point.
• Expect to stay at the assembly point until the situation is under control.
• Know that you might be interviewed by law enforcement.
• Do not leave the assembly point until instructed by law enforcement.


- **Adverse Weather Shelter:** WINDS/TORNADO
  1. Supervisors notify personnel of weather conditions.
  2. If there is a watch, direct securing / sheltering of outside equipment / material if time permits.

3. If there is a warning notify personnel to take immediate cover. ROOM #_3_____
Examples:
a. Lowest lever, and most interior room.
b. Inside hallway at the lowest level of the building.
c. Under a piece of sturdy furniture such as a workbench, heavy table, or desk.
d. If outdoors, get inside building or shelter if possible. If there is no time to get indoors, lie in a ditch or low-lying area and use your arms to protect the head and neck.
4. If possible, monitor local radio / television stations for current information.
5. Do not leave the facility until given the “ALL CLEAR”.
6. Up-channel information through the chain-of-command; call your Unit Control Center to report injuries and building damage.

EARTHQUAKE

1. If inside, stay inside and crawl under a desk or get next to a solid or bulky object, curl up into a fetal position and stay put until the shaking stops and you are sure it is safe to exit.
2. Stay away from glass, windows, outside doors and walls, and anything that could fall such as lighting fixtures or furniture.
3. After the shaking stops, supervisors help evacuate the building, turning off utilities where possible, and secure classified material.
4. Once outside, get to an open area away from buildings or unstable objects. If possible, go to the designated rally point. If outside during an earthquake, remain outside and locate to an open area.
5. Once personnel have cleared the building, do not allow anyone to re-enter damaged buildings.
6. Supervisors conduct accountability of personnel and report personnel status to your Unit Control Center.
7. Perform first aid (if needed).

Emergency Evacuation Route Image:



Power Pro Emergency Evacuation Route.jpeg

Emergency Equipment and Safety Board

Safety Bulletin Board Location: The Safety Bulletin Board is located on the wall of the main entrance hallway

FIRE EXTINGUISHERS
There are 3 fire extinguishers in the building. The first extinguisher is in the main office area, mounted on the corner of the wall across from the bathroom. The second extinguisher is in the maintenance bay to the right of the washer and dryer, mounted on a steel support beam. The third extinguisher is in the maintenance bay next to the building exit door, mounted on a steel support beam.


FIRE ALARMS
There are two fire alarm pull stations in the building. The first is located next to the building exit door in the office area. The second is located next to the building exit door in the maintenance bay.

EYE WASH STATION
There is one eye wash station in the building. It is located in the maintenance bay on the same wall as the offices. It is labeled with a sign on the wall, and a

black/yellow striped area on the floor.

FIRST AID KIT
There is one First Aid Kit in the building. It is located in the maintenance bay on the wall next to the utility sink. The utility sink is to the left of the washer and dryer.

Emergency Equipment Maps / AED & Fire Extinguisher Location Photos:



Power Pro Emergency Evacuation Route.jpeg

Traffic Safety Program

DAF Traffic Safety Program (DAFI 91-207): Train personnel on mandatory use of seat belts and helmets, speed limits, local traffic hazards, spotters while backing, vehicle training requirements, and restrictions on electronic device use while operating vehicles on- or off-base.

Seat Belts / Occupant Restraints: All persons operating or riding in motor vehicles must wear installed restraint systems as prescribed by the manufacturer. Drivers are responsible for ensuring all passengers are briefed on and use required restraints.

Motorcycle / ATV Training: Personnel must complete required safety training before riding a motorcycle, and local units should address required PPE, licensing, refresher training, and safety representative contacts.

Pedestrian / Bicycle Awareness: Emphasize local roadway crossing hazards, visibility requirements, spotter use, and other pedestrian or bicycle precautions specific to the installation.


Local Traffic Hazards / Vehicle Notes:
DAF Traffic Safety Program (DAFI 91-207): Train personnel on mandatory use of seat belts and helmets, speed limits, local traffic hazards, spotters while backing, vehicle training requirements, and restrictions on electronic device use while operating vehicles on- or off-base.
Seat Belts / Occupant Restraints: All persons operating or riding in motor vehicles must wear installed restraint systems as prescribed by the manufacturer. Drivers are responsible for ensuring all passengers are briefed on and use required restraints.
Motorcycle / ATV Training: Personnel must complete required safety training before riding a motorcycle, and local units should address required PPE, licensing, refresher training, and safety representative contacts.
Pedestrian / Bicycle Awareness: Emphasize local roadway crossing hazards, visibility requirements, spotter use, and other pedestrian or bicycle precautions specific to the installation.

Local Traffic Hazards / Vehicle Notes:
Main Gate (Main / North Gate) High-volume commercial and POV traffic. Heavy equipment transit is restricted during peak hours (0630-0830 and 1530-1730). Use caution when navigating barriers designed for Force Protection.
Commercial Gate (South Gate) Primary entry point for construction deliveries and oversized loads. Watch for blind spots, slow-turning semi-trucks, and security check queues blocking the lane.
Airfield / Flightline Access Gates ✈ FOD (Foreign Object Damage) Hazards: Ensure tires are checked and cleared of stones or debris before entering airfield access points. Ground equipment must yield to all taxiing aircraft and emergency response vehicles.
Pavement Maintenance Zones ⚠ Transition zones between gravel yards and paved base roads. Mud and debris tracked onto public base roads by heavy equipment must be cleared immediately to prevent motorcycle and vehicle slippage.

Vehicle Training & Documentation
To legally operate GMVs and specialized construction equipment, training must be explicitly tracked and documented:
AF Form 2293 (USAF Motor Vehicle Operator Identification Card): Must be carried by the operator, detailing every specific class of equipment they are authorized to operate (e.g., graders, loaders, dump trucks).
AF Form 483 (Flightline Driver's License): Must be in possession of any operator driving on the airfield flightline, complete with current annual flightline driver training certification

Motorcycle Safety Representatives / Traffic Contacts:
USR-MSgt Kelley

Safety Contacts
Base Safety Office (436 AW/SE): 302-677-2204 (For reporting roadway safety hazards or vehicle mishaps)
Security Forces Desk (SFS dispatch): 302-677-6664 (For traffic control, escort assistance, or road blockages)
CE Control Center (U-Drive): 302-677-4654 (For local road maintenance and heavy vehicle routing coordination)



No routine-use GVO risk assessment files uploaded.

Reporting Unsafe Equipment, Conditions, or Procedures

Notify the supervisor immediately when unsafe equipment, conditions, or procedures are identified. Personnel may report hazards without fear of retaliation, coercion, discrimination, or reprisal.

- **DAF Form 457:** Use to document and elevate unsafe conditions, equipment, or processes.
- **SAFEREP:** Use the approved mishap or hazard reporting channel for additional reporting when directed by local procedures.


Safety Reporting … All In One Place


SAFEREP APP!


Why Safety Reporting?

Quickly and easily tell safety about safety issues you see

- In the dorms
- At work
- Anywhere on base
- In flight
- While maintaining aircraft
- On the ramp







What to report?

- Dangerous conditions
- "Near miss" events
- Aviation specific reporting
- Cultural issues that could lead to an accident, damage, or injury
- Supervisor mishap report

Report anonymously
Reports go direct to the safety office

New name, new website, new app, and a whole new look

SAFEREP is a web- and app-based way for members from every career field to identify hazards and report near-misses and even some mishaps directly to their safety offices using any computer or mobile device.

SAFEREP

Download to your mobile device from your preferred App Store

Or

Go to https://saferep.safety.af.mil









Reporting Unsafe Equipment Reference Files:

- Hazard Report AF Form 457.pdf

Please wait...

If this message is not eventually replaced by the proper contents of the document, your PDF viewer may not be able to display this type of document.

You can upgrade to the latest version of Adobe Reader for Windows®, Mac, or Linux® by visiting http://www.adobe.com/go/reader_download.

For more assistance with Adobe Reader visit http://www.adobe.com/go/acrreader.

Windows is either a registered trademark or a trademark of Microsoft Corporation in the United States and/or other countries. Mac is a trademark of Apple Inc., registered in the United States and other countries. Linux is the registered trademark of Linus Torvalds in the U.S. and other countries.

Documentation and Review

AF Form 55 will be used to document safety, fire and health training unless other documentation is specified elsewhere. Documentation will be maintained by the supervisor within the work center and will contain the following minimum data: trainee name (last, first, middle initial), type of training and date of training. Neither the trainer or trainee signature is required unless specified in writing by the applicable chain of authority. The 14 mandatory items can be documented as one item, i.e., course code for JSTO mandatory training. Job specific items and any additional training identified in a BE survey will be documented individually, as appropriate.

Bioenvironmental Workplace Survey: No Bioenvironmental Workplace Survey uploaded.

Applicable Job Hazard Analyses: No Job Hazard Analysis files uploaded.

Annual Review Log:
Record the supervisor annual review history here.

Trainee Name	Employee ID / Last 4	Date Trained	Trainer / Supervisor Signature