

work order: _____
date: _____

property: Beacon Hill
address: 2321 Troost Ave
city & state: Kansas City, MO zip: 64108
contact: _____ ph: _____

customer: _____
address: _____
city & state: _____ zip: _____
contact: _____ ph: _____

this inspection performed in accordance with the applicable portions of nfpa 25 as defined in jayhawk fire sprinkler's performance specifications

Hydrant #:	#1	#2						
Location:	middle of street-2401 troost	west corner of 25th & troost						
Nozzle:	2-1/2"	2-1/2"	2-1/2"	2-1/2"	2-1/2"	2-1/2"	2-1/2"	2-1/2"
Static:	85	80						
Residual:	80	70						
Pitot:	diffuser	diffuser						
Flow:	1500	1411	0	0	0	0	0	0
Calculation @ 20 psi:	5993	3713	#NUM!	#NUM!	#NUM!	#NUM!	#NUM!	#NUM!
Time Flushed (in minutes):	2	2						
Water Used (in gallons):	3000	2822	0	0	0	0	0	0
Paint: (color)								
Chains:	OK	OK						
Caps:	OK	OK						
Stems:	OK	OK						
Packing:	OK	OK						
O-rings:	OK	OK						
Top Nut:	OK	OK						
Valve:	OK	OK						
Valve Seat:	OK	OK						
Condition of Water:	OK	OK						
Remarks:								

inspector's signature: David Braughton Nicet Cert

date: 09.11.17

owner/repres. signature: _____

date: _____