



# Hydrant Inspection

work order: \_\_\_\_\_  
date: 11/8/17

property: Near Guinotte & Montgall  
address: Guinotte & Montgall  
city & state: Kansas City, MO zip: \_\_\_\_\_  
contact: \_\_\_\_\_ ph: \_\_\_\_\_

customer: CMG Fire Protection Engineering  
address: \_\_\_\_\_  
city & state: \_\_\_\_\_ zip: \_\_\_\_\_  
contact: Cindy Gier ph: \_\_\_\_\_

this inspection performed in accordance with the applicable portions of nfpa 25 as defined in jayhawk fire sprinkler's performance specifications

|                            |                                  |  |                           |  |  |  |  |  |
|----------------------------|----------------------------------|--|---------------------------|--|--|--|--|--|
| Hydrant #:                 | SE Corner of Guinotte & Montgall |  | NE of Guinotte & Montgall |  |  |  |  |  |
| Location:                  |                                  |  |                           |  |  |  |  |  |
| Nozzle:                    | 2-1/2"                           |  | 2-1/2"                    |  |  |  |  |  |
| Static:                    | 150                              |  | 153                       |  |  |  |  |  |
| Residual:                  | 120                              |  | 130                       |  |  |  |  |  |
| Pitot:                     | 58                               |  | 92                        |  |  |  |  |  |
| Flow:                      | 1278                             |  | 1609                      |  |  |  |  |  |
| Calculation @ 20 psi:      | 2821                             |  | 4152                      |  |  |  |  |  |
| Time Flushed (in minutes): |                                  |  |                           |  |  |  |  |  |
| Water Used (in gallons):   | 0                                |  | 0                         |  |  |  |  |  |
| Paint: (color)             |                                  |  |                           |  |  |  |  |  |
| Chains:                    | OK                               |  | OK                        |  |  |  |  |  |
| Caps:                      | OK                               |  | OK                        |  |  |  |  |  |
| Stems:                     | OK                               |  | OK                        |  |  |  |  |  |
| Packing:                   | OK                               |  | OK                        |  |  |  |  |  |
| O-rings:                   | OK                               |  | OK                        |  |  |  |  |  |
| Top Nut:                   | OK                               |  | OK                        |  |  |  |  |  |
| Valve:                     | OK                               |  | OK                        |  |  |  |  |  |
| Valve Seat:                | OK                               |  | OK                        |  |  |  |  |  |
| Condition of Water:        | OK                               |  | OK                        |  |  |  |  |  |
| Remarks:                   |                                  |  |                           |  |  |  |  |  |

inspector's signature: Jeff Ryun Nicet Cert date: 11/8/17

owner/repres. signature: \_\_\_\_\_ date: \_\_\_\_\_