



JTECH ENGINEERING
PANEL MAKER - AUTOMATION - GENERAL TRADING

PT.JIDOUKA TEKNOLOGI INDONESIA

JABODETABEK :

Perum Graha Persada Jl. Persada 7 No 26 ,Cibitung
Kab. Bekasi Jawa Barat 1724

Phone : 087870386649

NPWP : 042.673.277.2-427.000

EMAIL : marketing@jtech-engineer.com

WEB : www.jtech-engineer.com

TEST REPORT

Customer	PT. XD SAKTI INDONESIA	No Doc	JTI-2605-004 /2025SK017 TEST REPORT
Project Name	PENGADAAN TRANSFORMATOR 60 MVA SIDOARJO	Job Order	PO.26.0041.ITEM
Panel Name	PANEL MARSHALLING KIOSK SFZ-60000/150	Date	MEI 2026

1. VISUAL CHECKLIST

NO	DESKRIPSI	CHECK
1	Periksa tata letak komponen yang terpasang sesuai dengan desain gambar	
2	Periksa dimensi komponen dan grounding masing – masing komponen harus terkoneksi pada busbar	
3	Periksa dan pastikan merek dan model sesuai dengan list komponen pada desain gambar	
4	Periksa dan pastikan kekencangan koneksi setiap wiring harus kencang dan dilakukan marking pada komponen yang telah dicek	
5	Periksa marking komponen,label komponen dal label phasa harus sesuai dengan desain gambar	

2. INDIVIDUAL CHECKLIST

NO	QTY	MARK	EQUIPMENT	MANUFACTURER	TYPE	TECHNICAL DATA	FITTING	LABEL	FUCTION TEST
1	1	QF1	CIRCUIT BREAKER FOR MAIN SUPPLY	SCHNEIDER	Acti9 IC60 + Aux Contact	400V AC 3Ø 50Hz 63A			
2	1	ST1	MULTIFUNCTION CONTROL RELAY	OMRON	K8AK-PM2	CONTROL 400V AC, 2C/O			
3	1	ST2	VOLTAGE DROP RELAY	SCHNEIDER	RM22UB34	80V ADC, 2C/O 8A			

4	1	QF2	CIRCUIT BREAKER FOR DC MAIN SUPPLY	SCHNEIDER	Acti9 C60HDC + Aux Contact	110V DC 2Ø 10A			
5	3	QF3~ QF5	CIRCUIT BREAKER	SCHNEIDER	Acti9 C60HDC + Aux Contact	110V DC 2Ø 4A			
6	1	QF6	CIRCUIT BREAKER	SCHNEIDER	Acti9 IC60 + Aux Contact	230V AC 2Ø 50Hz 20A			
7	2	QF7, QF12	CIRCUIT BREAKER	SCHNEIDER	Acti9 IC60 + Aux Contact	230V AC 2Ø 50Hz 2A			
8	1	QF8	CIRCUIT BREAKER	SCHNEIDER	Acti9 IC60 + Aux Contact	230V AC 2Ø 50Hz 4A			
9	2	QF9, QF10	CIRCUIT BREAKER	SCHNEIDER	Acti9 IC60 + Aux Contact	230V AC 2Ø 50Hz 16A			
10	1	QF11	CIRCUIT BREAKER	SCHNEIDER	Acti9 IC60 + Aux Contact	400V AC 3Ø 50Hz 10A			
11	3	1QF ~ 3QF	CIRCUIT BREAKER	SCHNEIDER	iC-60N + Aux Contact	230V AC 3Ø 50Hz 6A			
12	3	1KM ~ 3KM	CONTACTOR 3 POLE	SCHNEIDER	LC1-D09 KUE	3P, 50Hz, 9A, Coil: 110 V DC			
13	3	1RJ ~ 3RJ	THERMAL RELAY	SCHNEIDER	LRD-07	ADJ. 1,60- 2,50 A, SETTING 2,1A			
14	2	SC	STOP KONTAK	HAGER / EQUAL	SCHUKO	1PH 10/16A			
15	1	EH	HEATER	SUNGHO	CONHEAT	230V AC, 50 HZ, 100W			

16	1	TS	THERMOSTAT FOR HEATER	FORT	NSYCCOTH C	0~60'C 1NO/NC			
17	2	LS	LIMIT SWITCH	OMRON	Z - Series	-			
18	1	EL1	PANEL ILLUMINATION	LOCAL	LED	30 WATT, 230 VAC			
19	1	EL2	PANEL ILLUMINATION						
20	1	PS1	POWER SUPPLY	MEAN WELL	NDR-240-24	230 VAC TO 24 VDC 5A			
21	1	PS2	POWER SUPPLY						
22	10	KX11~KX1 5, KX21~KX2 5	MINIATURE RELAY	SCHEIDER/EQUAL	RXM2+SOCKET	110 VDC, 4CO			
23	1	KT	WEEKLY TIME RELAY	SELECT/EQUAL	TS2M1	230V AC			
24	1	S01	SELECTOR SWITCH	K & N	CA10-A221-600	POSITION, LOCAL - REMOTE, 2 POLE			
25	2	S02, S03	SELECTOR SWITCH	K & N	CA10-A211-600	POSITION, AUTO OFF - MANUAL, 2 POLE			
26	45	X2.2, X4	TERMINAL BLOCK	PHOENIX / EQUAL	UT6	Screw TYPE			
27	11	X3	TERMINAL BLOCK	PHOENIX / EQUAL	URTK/S	Screw Type			

28	270	X1, X2.1, X2.3 ~ X2.7	TERMINAL BLOCK	PHOENIX / EQUAL	UK5-MTK-P/P	PIN-KNIFE TYPE			
29	10	X5	TERMINAL BLOCK	PHOENIX / EQUAL	UIK-35	Screw Type			
30	2	DTC-48	DUCTING CABLE	PUMA	PERFORATED	48x100 mm			
31	4	DTC-70	DUCTING CABLE	PUMA	PERFORATED	70x100 mm			
32	4	DTC-100	DUCTING CABLE	PUMA	PERFORATED	100x100 mm			
33	1	PB	PUSH BUTTON	SCHNEIDER	XB5AL73415	-			
34	4	KA1~KA4	CONTACTOR RELAY	SCHNEIDER	CA3KN22FD	3NO 1NC, Coil 110V DC			
35	2	NYAF	INTERNAL CABLE	LOCAL/IMPORT	-	Ø1.5, Ø2.5, Ø4			
36	2	M10,M11	AMPERE METER	HELES/EQUAL	K8AKPM2	0~2 A, Cls 2,5			
37	1	LIYCY	INTERNAL CABLE	LOCAL/IMPORT	-	Ø1.5, Ø2.5, Ø4			
38	1	ACC	OTHER ACCESSORIES	LOCAL/IMPORT	-	Ø0.5			

	Company	Name	Signature
Check By	PT. JIDOUKA TEKNOLOGI INDONESIA		

