



Lecture 12

GENERATOR MODEL

Agenda

R.D. del Mundo
Ivan B.N.C. Cruz
Christian. A. Yap



NETWORK ELEMENT	POSITIVE	NEGATIVE	ZERO

Lecture Outcomes

at the end of the lecture, the student must be able to ...

- Draw the Generator Models used in Power System Analysis.
- Determine the difference in the sequence circuits of ground or ungrounded generators.

EEE 103

Introduction to Power Systems


Power System Modeling Part 2

Generator and Transformer Models

Generator Model

Generalized Machine Model

Constructional Details of Synchronous Machine



Stator:


distributed three-phase winding (a, b, c)

Rotor:

DC field winding (F) and short-circuited damper windings (D, Q)

Generalized Machine Model

Primitive Coil Representation



$$v = Ri + \frac{d\lambda}{dt}$$

Generalized Machine Model

Voltage Equations for the Primitive Coils

For the stator windings

$$\begin{aligned} \underline{v}_a &= \underline{R}_a \underline{i}_a + \frac{d\underline{\lambda}_a}{dt} \\ v_b &= R_b i_b + \frac{d\lambda_b}{dt} \\ v_c &= R_c i_c + \frac{d\lambda_c}{dt} \end{aligned}$$

For the rotor windings

$$\begin{aligned} v_F &= R_F i_F + \frac{d\lambda_F}{dt} \\ v_D &= R_D i_D + \frac{d\lambda_D}{dt} \\ v_Q &= R_Q i_Q + \frac{d\lambda_Q}{dt} \end{aligned}$$

Note: The D and Q windings are shorted (i.e. $v_D = v_Q = 0$).

$$\begin{bmatrix} \underline{v}_{abc} \\ \underline{v}_{FDQ} \end{bmatrix} = \begin{bmatrix} \underline{R}_{abc} & \\ & \underline{R}_{FDQ} \end{bmatrix} \begin{bmatrix} \underline{i}_{abc} \\ i_{FDQ} \end{bmatrix} + p \begin{bmatrix} \underline{\lambda}_{abc} \\ \underline{\lambda}_{FDQ} \end{bmatrix} \quad \lambda = Li$$

Generalized Machine Model

The flux linkage equations are:

$$\begin{bmatrix} \lambda_a \\ \lambda_b \\ \lambda_c \\ \lambda_F \\ \lambda_D \\ \lambda_Q \end{bmatrix} = \begin{bmatrix} L_{aa} & L_{ab} & L_{ac} & L_{aF} & L_{aD} & L_{aQ} \\ L_{ba} & L_{bb} & L_{bc} & L_{bF} & L_{bD} & L_{bQ} \\ L_{ca} & L_{cb} & L_{cc} & L_{cF} & L_{cD} & L_{cQ} \\ L_{Fa} & L_{Fb} & L_{Fc} & L_{FF} & L_{FD} & L_{FQ} \\ L_{Da} & L_{Db} & L_{Dc} & L_{DF} & L_{DD} & L_{DQ} \\ L_{Qa} & L_{Qb} & L_{Qc} & L_{QF} & L_{QD} & L_{QQ} \end{bmatrix} \begin{bmatrix} i_a \\ i_b \\ i_c \\ i_F \\ i_D \\ i_Q \end{bmatrix}$$

or

$$\begin{bmatrix} \underline{\lambda}_{abc} \\ \underline{\lambda}_{FDQ} \end{bmatrix} = \begin{bmatrix} [L_{SS}] & [L_{SR}] \\ [L_{RS}] & [L_{RR}] \end{bmatrix} \begin{bmatrix} \underline{i}_{abc} \\ \underline{i}_{FDQ} \end{bmatrix}$$

Generalized Machine Model

COIL INDUCTANCES

Stator Self Inductances

$$L_{aa} = L_s + L_m \cos 2\theta_e$$

$$L_{bb} = L_s + L_m \cos(2\theta_e + 120^\circ)$$

$$L_{cc} = L_s + L_m \cos(2\theta_e - 120^\circ)$$

Stator-to-Stator Mutual Inductances

$$L_{ab} = L_{ba} = -M_s + L_m \cos(2\theta_e - 120^\circ)$$

$$L_{bc} = L_{cb} = -M_s + L_m \cos 2\theta_e$$

$$L_{ca} = L_{ac} = -M_s + L_m \cos(2\theta_e + 120^\circ)$$

Generalized Machine Model

COIL INDUCTANCES

Stator-to-Rotor Mutual Inductances

$$L_{aF} = L_{Fa} = L_{aF} \cos \theta_e$$

$$L_{bF} = L_{Fb} = L_{aF} \cos(\theta_e - 120^\circ)$$

$$L_{cF} = L_{Fc} = L_{aF} \cos(\theta_e + 120^\circ)$$

$$L_{aQ} = L_{Qa} = -L_{aQ} \sin \theta_e$$

$$L_{bQ} = L_{Qb} = -L_{aQ} \sin(\theta_e - 120^\circ)$$

$$L_{cQ} = L_{Qc} = -L_{aQ} \sin(\theta_e + 120^\circ)$$

$$L_{aD} = L_{Da} = L_{aD} \cos \theta_e$$

$$L_{bD} = L_{Db} = L_{aD} \cos(\theta_e - 120^\circ)$$

$$L_{cD} = L_{Dc} = L_{aD} \cos(\theta_e + 120^\circ)$$

Generalized Machine Model

COIL INDUCTANCES

Rotor Self Inductances

$$L_{FF} = L_{FF}$$

$$L_{DD} = L_{DD}$$

$$L_{QQ} = L_{QQ}$$

Rotor-to-Rotor Mutual Inductances

$$L_{FD} = L_{DF} = L_{FD}$$


$$L_{FQ} = L_{QF} = 0$$

$$L_{DQ} = L_{QD} = 0$$

Generalized Machine Model


Equivalent Coil Representation

Rotor coils FDQ stationary
Stator coils abc rotating



Generalized Machine Model

Transformation from abc to Odq



Note: The d and q windings are pseudo-stationary. The O axis is perpendicular to the d and q axes.

Generalized Machine Model

Park's Transformation Matrix

$$[P] = \sqrt{\frac{2}{3}} \begin{bmatrix} \frac{1}{\sqrt{2}} & \frac{1}{\sqrt{2}} & \frac{1}{\sqrt{2}} \\ \cos \theta_e & \cos(\theta_e - 120) & \cos(\theta_e + 120) \\ -\sin \theta_e & -\sin(\theta_e - 120) & -\sin(\theta_e + 120) \end{bmatrix}$$
$$[P]^{-1} = \sqrt{\frac{2}{3}} \begin{bmatrix} \frac{1}{\sqrt{2}} & \cos \theta & -\sin \theta_e \\ \frac{1}{\sqrt{2}} & \cos(\theta_e - 120) & -\sin(\theta_e - 120) \\ \frac{1}{\sqrt{2}} & \cos(\theta_e + 120) & -\sin(\theta_e + 120) \end{bmatrix}$$

Generalized Machine Model

After Park's Transformation

Voltage Equations

$$(1) \quad v_o = R_a i_o + p \lambda_o$$

$$(2) \quad v_d = R_a i_d + p \lambda_d - \omega_m \lambda_q$$

$$(3) \quad v_q = R_a i_q + p \lambda_q + \omega_m \lambda_d$$

$$(4) \quad v_F = R_F i_F + p \lambda_F$$

$$(5) \quad v_D = R_d i_D + p \lambda_D = 0$$

$$(6) \quad v_Q = R_Q i_Q + p \lambda_Q = 0$$

Flux Linkages

$$(1) \quad \lambda_o = L_{oo} i_o$$

$$(2) \quad \lambda_d = L_{dd} i_d + L_{dF} i_F + L_{dD} i_D$$

$$(3) \quad \lambda_q = L_{qq} i_q + L_{qQ} i_Q$$

$$(4) \quad \lambda_F = L_{Fd} i_d + L_{FF} i_F + L_{FD} i_D$$

$$(5) \quad \lambda_D = L_{Dd} i_d + L_{DF} i_F + L_{DD} i_D$$

$$(6) \quad \lambda_Q = L_{Qq} i_q + L_{QQ} i_Q$$

Generalized Machine Model

$$L_{oo} = L_S - 2M_S$$

$$L_{dd} = L_S + M_S + \frac{3}{2}L_m$$

$$L_{qq} = L_S + M_S - \frac{3}{2}L_m$$

$$L_{dF} = \sqrt{\frac{3}{2}}L_{aF}$$

$$L_{dD} = \sqrt{\frac{3}{2}}L_{aD}$$

$$L_{qQ} = \sqrt{\frac{3}{2}}L_{aQ}$$

$$L_{Fd} = \sqrt{\frac{3}{2}}L_{aF}$$

$$L_{Dd} = \sqrt{\frac{3}{2}}L_{aD}$$

$$L_{Qq} = \sqrt{\frac{3}{2}}L_{aQ}$$


Note: All inductances are constant.

Steady-State Analysis

Using Park's transformation of balance 3-phase voltage and currents of generators

$$\vec{V}_a = R_a \left(-\vec{I}_a \right) + jX_s \left(-\vec{I}_a \right) + \vec{E}_g$$

$$\vec{E}_g = R_a \vec{I}_a + jX_s \vec{I}_a + \vec{V}_a$$



Equivalent Circuit of Cylindrical Rotor Synchronous Generator

Equivalent Circuit of Generators

Positive-Sequence Impedance:

X_d'' = Direct-Axis Subtransient Reactance

X_d' = Direct-Axis Transient Reactance

X_d = Direct-Axis Synchronous Reactance

Negative-Sequence Impedance:

$X_2 = \frac{1}{2} (X_d'' + X_q'')$ for a salient-pole machine

$X_2 = X_d''$ for a cylindrical-rotor machine


Zero-Sequence Impedance:

$$0.15X_d'' \leq X_0 \leq 0.6X_d''$$


Equivalent Circuit of Generators

Grounded-Wye Generator


The sequence networks for the grounded-wye generator are shown below.



Positive
Sequence



Negative
Sequence




Zero Sequence


Equivalent Circuit of Generators

Grounded-Wye through an Impedance


If the generator neutral is grounded through an impedance Z_g , the zero-sequence impedance is modified as shown below.



Positive
Sequence



Negative
Sequence




Zero Sequence


Equivalent Circuit of Generators

Ungrounded-Wye Generator


If the generator is connected ungrounded-wye or delta, no zero-sequence current can flow. The sequence networks for the generator are shown below.



Positive
Sequence



Negative
Sequence



Zero Sequence