

	COROMANDEL INTERNATIONAL LIMITED (Crop Protection Chemicals)	
	Preventive Maintenance or Inspection Checkpoints-SOV	Page 1 of 1

SECTION:			PM DATE:	
TAG NO:				
DESCRIPTION/LOCATION				
SR.	JOB	POINTS TO BE CHECKED	YES/NO	REMARK
1	SOLENOID VALVE	Is permit taken from the plant?		
2		Is the timer panel off & depressurize the process line?		
3		Is diaphragm ruptured?		
4		Is diaphragm replaced?		
5		Is the coil function is ok?		
6		Is the plunger and spring ok?		
7		Are the nuts and bolts tighten properly?		
8		Is the cable gland proper?		
9		Is the timer panel ON after job completion?		
10		Is there maintain the 5'S and close the permit?		

Special Remarks:

Checked by	Verified by	Reviewed by