

 COROMANDEL INTERNATIONAL LIMITED	Format No.	INST/F/11
	Issue No.	01
	Issue Date	03/10/2017
	Revision No.	01
	Revision Date:	03/10/2017

PREVENTIVE MAINTENANCE CHECKPOINTS-LEVEL/PRESSURE/FLOW/TEMP TRANSMITTER				
SECTION:			PM DATE:	
TAG NO:				
DESCRIPTION/LOCATION				
SR.	JOB	POINTS TO BE CHECKED	CHECK (v)	REMARK
1	LEVEL/PRESSURE/FLOW/TEMP TRANSMITTER	Take permit from the plant		
2		Isolate from process and drain the fluid		
3		Clean the transmitter		
4		Check zero of transmitter, if not ok then set it to zero		
5		Take into line and process value		
6		If not ok then remove from location and take into workshop		
7		Check the transmitter in inst. Lab and set it		
8		Fix back to original location and take into line		
9		Check the cable gland if not proper than fix it properly and tighten all connections		
10		Update the instrument calibration tag and cover with polythene		
11		Close the permit		
12		Note down reading in calibration record and mention all tags in shift Log book		

Special Remarks:		
Checked by:	Verified by:	Reviewed by: