

 COROMANDEL INTERNATIONAL LIMITED	Format No.	INST/F/01
	Issue No.	01
	Issue Date	03/10/2017
	Revision No.	01
	Revision Date:	03/10/2017

PREVENTIVE MAINTENANCE CHECKPOINTS-PRESSURE/LEVEL/FLOW SWITCHES				
SECTION:			PM DATE:	
TAG NO:				
DESCRIPTION/LOCATION				
SR.	JOB	POINTS TO BE CHECKED	CHECK (v)	REMARK
1	PRESSURE/LEVEL/FLOW SWITCHES	Take permit from the plant		
2		Isolate the system		
3		Remove switch from location		
4		Take to test bench and connect air supply		
5		Check the contact (NO/NC) at desire point		
6		Fix back at original position with all lubricants		
7		Put the service date tag		
8		Take in to line		
9		Close the permit from the plant		
10		Mention preventive record in shift log book		

Special Remarks:		
Checked by:	Verified by:	Reviewed by: