

 COROMANDEL INTERNATIONAL LIMITED	Format No.	INST/F/03
	Issue No.	01
	Issue Date	03/10/2017
	Revision No.	01
	Revision Date:	03/10/2017

PREVENTIVE MAINTENANCE CHECKPOINTS-GAS LEAK DETECTORS CS2/CL2/NH3				
SECTION:			PM DATE:	
TAG NO:				
DESCRIPTION/LOCATION				
SR.	JOB	POINTS TO BE CHECKED	CHECK (v)	REMARK
1	GAS LEAK DETECTOR CS2/CL2/NH3	Take permit from the plant		
2		Isolate the power and clean the instrument		
3		Check all connections and tighten it		
4		Switch on power again		
5		Take the sample gas test kit bottle and keep it at sensor		
6		Observe the alarm/contact and reading on display		
7		Set it at required ppm & check again for conformity		
8		Fix back to original location, update instrument calibration tag and cover with polythene		
9		Note down reading in calibration card and mention all tags in shift Log book		
10		Close the permit and handover equipment		

Special Remarks:		
Checked by:	Verified by:	Reviewed by: