

 <b>COROMANDEL INTERNATIONAL LIMITED</b>	Format No.	INST/F/10
	Issue No.	01
	Issue Date	03/10/2017
	Revision No.	01
	Revision Date:	03/10/2017

PREVENTIVE MAINTENANCE CHECKPOINTS-PRV				
SECTION:			PM DATE:	
TAG NO:				
DESCRIPTION/LOCATION				
SR.	JOB	POINTS TO BE CHECKED	CHECK (v)	REMARK
1	PRV	Take permit from the plant		
2		Isolate system & remove valve from location		
3		Overhaul the valve		
4		Take to test bench and connect air supply		
5		Test it to the required air pressure		
7		Fix back to the original position with all lubricants		
8		Take into line		
9		Update the instrument calibration tag and close the permit		
10		Mention all tags in shift Log book		

Special Remarks:		
Checked by:	Verified by:	Reviewed by: