

 COROMANDEL INTERNATIONAL LIMITED	Format No.	INST/F/09
	Issue No.	01
	Issue Date	03/10/2017
	Revision No.	01
	Revision Date:	03/10/2017

PREVENTIVE MAINTENANCE CHECKPOINTS-LEVEL GAUGES (Side mounted magnetic, Glass tube, Reflux, Float & Board)				
SECTION:			PM DATE:	
TAG NO:				
DESCRIPTION/LOCATION				
SR.	JOB	POINTS TO BE CHECKED	CHECK (v)	REMARK
1	LEVEL GAUGES (Side mounted magnetic, Glass tube, Reflux, Float & Board)	Take permit from the plant		
2		Isolate the gauge and drain liquid		
3		Remove indicator and clean it with water/steam/cloth		
4		Remove float and check for leakage, install back wherever applicable		
5		Check the water in glass tube and clean follower if applicable		
6		Check scale alignment and fix it properly		
7		Fix the gauge and grease all moving parts		
8		Update the instrument calibration tag		
9		Close the permit and handover		
10		Mention all tags in shift Log book		

Special Remarks:		
Checked by:	Verified by:	Reviewed by: