

【별표 9】

이중보온관 규격

(제14조 제1항 관련) <개정 12.11.5., 25.09.01.>

NOMINAL PIPE DIA. (A)	CARRIER PIPE			INSULATION THK (mm)	OUTER JACKET			LENGTH (m)	이격 거리 (mm)
	MATERIAL	WALL THK (mm)	O.D (mm)		STD THK (mm)		O.D (mm)		
					FITTING	PIPE			
20	SPPS 250S/E	2.9	27.2	26.8	2.8	3.0	90	6	100
25	”	3.4	34.0	23.4	2.8	3.0	90	6	100
32	”	3.6	42.7	28.8	3.3	3.0	110	6	100
40	”	3.7	48.6	25.8	3.3	3.0	110	6	100
50	”	3.9	60.5	27.2	3.5	3.0	125	6	150
65	”	4.5	76.3	26.5	3.9	3.0	140	6	150
80	”	4.5	89.1	29.9	4.0	3.0	160	6	150
100	”	4.9	114.3	36.2	4.4	3.5	200	6	200
125	”	5.1	139.8	35.6	4.9	3.5	225	12	200
150	SPPS 250S/E	5.5	165.2	34.4	5.5	4.0	250	12	250
200	SPPS 250 E	6.4	216.3	38.5	6.9	5.6	315	12	250
250	”	6.4	267.4	53.6	8.7	6.3	400	12	250
300	”	6.4	318.5	51.6	9.8	7.0	450	12	250
350	”	6.4	355.6	56.4	10.9	7.8	500	12	250
400	”	6.4	406.4	62.1	12.2	8.8	560	12	250
450	”	6.4	457.2	70.0	13.7	9.8	630	12	300
500	SPPS 250 E	6.4	508.0	82.4	15.5	11.1	710	12	300