

OSHA Report Plaza Ford

Complete On: 7/17/2024

Report Created By:

Russell Savage

757-944-6910

rsavage@autorisknow.com

Electrical issues misc.

Date of occurrence: July 17, 2024

Refrigerators and toaster ovens in the service area.



Employees are not properly maintaining their hoist controls or bypassing any automatic safety features.

High Risk

Date of occurrence: July 17, 2024

Bypassing safety measures with bungie cords



All vacant holes are not properly sealed off on electrical panel box.

Date of occurrence: July 17, 2024

Electrical panel has vacant hole.

