

OSHA Report **Nationwide Nissan/Kia**

Complete On: 7/16/2024

Report Created By:

Russ Savage

757-944-6910


rsavage@autorisknow.com

The fire extinguisher signs above the unit are not posted properly.

High Risk

Date of occurrence: July 16, 2024

Almost every fire extinguisher does not have signage above.



The eye wash container water supply has not been changed out properly based on manufacturer recommendations per solution used.

High Risk

Date of occurrence: July 16, 2024

Eye wash was not filled with water. In both service centers these must be filled.

All tanks holding flammable material are not properly grounded.

Date of occurrence: July 16, 2024

Tanks not tied down.



Air compressors are not marked with Automatic on/off signage.

Date of occurrence: July 16, 2024

No signage for auto start of Air Compressor



There are other miscellaneous electrical issues to note.

Date of occurrence: July 16, 2024

Detail area electric outlets need covers near water usage

