

OSHA Report **JIM MLADY** **NISSAN LLC**

Complete On: 8/08/2024

Report Created By:

Jim Perschke

847-975-2324

jperschke@autorisknow.com

Used batteries are not being stored in acid resistance leak proof containers and or on mat.

Date of occurrence: August 08, 2024

Found batteries all over shop area and parts on the floor



There are other miscellaneous electrical issues to note.

Date of occurrence: August 08, 2024


Box has vacant hole at bottom and no cover inside box when opened



The fire extinguisher signs above the unit are not posted properly.

Date of occurrence: August 08, 2024

Need new sign in service area, need sign in showroom



The eye wash equipment is not readily accessible.

Date of occurrence: August 08, 2024

Found Eye wash station laying on floor.



The eye wash equipment has not been tested and cleaned and documented weekly.

Date of occurrence: August 08, 2024

Weekly documentation is not being documented



All electrical cords are not in good working order (none frayed, cracked, taped, or spliced or ground missing on 3 prong plugs).

Date of occurrence: August 08, 2024

Found extension cord with damage to outside housing



Storage Containers not capped and or sealed properly

Date of occurrence: August 08, 2024

Found drum outside missing cap



All the Fire Extinguishers are not easily accessible.

Date of occurrence: August 08, 2024

Fire extinguisher blocked in parts



There is not clear access of at least 36" to all electrical panels.

Date of occurrence: August 08, 2024

this panel in parts is blocked for access



The fluorescent tubes are not stored properly.

Date of occurrence: August 08, 2024

Found this in closet across from parts counter and upper level.



The elevator has not been inspected.

Date of occurrence: August 08, 2024

Need to display inspection sheet in elevator.



Miscellaneous issues.

Date of occurrence: August 08, 2024

Grinder needs new plastic eye shield Brake Lathe should have sign requiring eye protection

