

# OSHA Report **Arnie Bauer** **Buick GMC** **Cadillac**

Complete On: 8/13/2024

Report Created By:

Jim Perschke

847-975-2324

[jperschke@autorisknow.com](mailto:jperschke@autorisknow.com)

**All secondary containers filled with chemicals are not properly labeled.**

Date of occurrence: August 13, 2024

*Found secondary spray bottles containing liquid not labeled*



**All the Fire Extinguishers are not easily accessible.**

Date of occurrence: August 13, 2024


*Found extinguisher access impeded*



**The fire extinguisher signs above the unit are not posted properly.**

Date of occurrence: August 13, 2024

*Found extinguishers missing signage*



## **There is not clear access of at least 36” to all electrical panels.**

Date of occurrence: August 13, 2024

*Found this panel blocked upstairs in parts*



## **All vacant holes are not properly sealed off on electrical panel box.**

Date of occurrence: August 13, 2024

*Found vacant uncovered holes in this breaker panel*



## **Fire Extinguisher missing or not properly mounted in dispensing area**

Date of occurrence: August 13, 2024

*Showroom Extinguisher needs mounting bracket and signage*



## Storage Containers not capped and or sealed properly

Date of occurrence: August 13, 2024

*Found these containers outside without caps, collection of rain water.*



## Used batteries are not being stored in acid resistance leak proof containers and or on mat.

Date of occurrence: August 13, 2024

*Found a few used batteries sitting around shop floor*



## All tanks holding flammable material are not properly grounded.

Date of occurrence: August 13, 2024

*Found several containers without the ground wire attached*



**There is no proper spacing on grinders; Tool rest 1/8” from grinding wheel. Tongue plate 1/4” from grinding wheel.**

Date of occurrence: August 13, 2024

*Grinder is missing tool rest and damaged safety glass*



**Hoists are not being maintained within mfg. specs, and inspected and serviced AND documented under the mfg. suggested frequency. Usually annually.**

Date of occurrence: August 13, 2024

*Noticed inspection dates look outdated from 2018*

