


MODEL NUMBER	NOMINAL SIZE	ACTUAL SIZE	AIR FLOW CFM'S	INITIAL RESISTANCE
DPD7-STD1	12X24X1	11-3/8X23-3/8X3/4	600	.12
DPD7-STD1	14X20X1	13-1/2X19-1/2X3/4	585	.12
DPD7-STD1	14X25X1	13-1/2X24-1/2X3/4	730	.12
DPD7-STD1	16X20X1	15-1/2X19-1/2X3/4	670	.12
DPD7-STD1	16X25X1	15-1/2X24-1/2X3/4	835	.12
DPD7-STD1	20X20X1	19-1/2X19-1/2X3/4	835	.12
DPD7-STD1	20X25X1	19-1/2X24-1/2X3/4	1040	.12
DPD7-STD1	20X30X1	19-1/2X29-1/2X3/4	1200	.12
DPD7-STD2	16X20X2	15-1/2X19-1/2X1-3/4	670	.14
DPD7-STD2	16X24X2	15-3/8X23-3/8X1-3/4	800	.14
DPD7-STD2	16X25X2	15-1/2X24-1/2X1-3/4	835	.14
DPD7-STD2	20X20X2	19-1/2X19-1/2X1-3/4	835	.14
DPD7-STD2	20X25X2	19-1/2X24-1/2X1-3/4	1040	.14
DPD7-STD2	24X24X2	23-3/8X23-3/8X1-3/4	1200	.14



STANDARD CONSTRUCTION

1. Fiberglass Media
2. Two Piece Beverage Board Frame

NOTES

1. Rated Velocity: 300 FPM
2. MERV 7 ASHRAE 52.2-2007
3. Class 2 Filter Per U.L. Standard 900
4. Maximum Operating Temperature: 200 deg. F
5. Final Resistance for 1" size is .50 " W.C.
Final Resistance for 2" size is 1.00" W.C.



P.O. Box 32578
Louisville, KY 40232
P: 866-247-4827
F: 502-961-0930
© www.airguard.com

CONTACT FACTORY TO
VERIFY REVISION LEVEL

TOLERANCES UNLESS OTHERWISE SPECIFIED

FRACTIONAL -
DECIMAL -
ANGLES -

ALL DIMENSIONS IN INCHES

DRAWING NAME

DPD7 THROW AWAY FILTER

APPROVED BY

K. Quinn

SPECIFICATION NO.

MKT-B-00569

PAGE

1 OF 1

SCALE

NONE

DWG. SIZE

A

REVISION

NEW

REVISION DATE

8/28/2008

CONFIDENTIAL - DO NOT COPY. THIS MATERIAL IS TRADE SECRET AND PROPRIETARY BEING EXCLUSIVELY OWNED BY CLC AIR. THE EXPRESSION OF THE INFORMATION CONTAINED HEREIN IS PROTECTED UNDER FEDERAL COPYRIGHT LAWS AND ALL COPYING IS PROHIBITED AND MAY BE SUBJECT TO CRIMINAL PENALTIES.