IEEE Access
Multidisciplinary | Rapid Review | Open Access Journal

*Digital Object Identifier*

# Physics-Based Event Attribution From Sparse PMUs With Recovery Memory

**JORGE LUIS MAYORGA TABORDA[1], YESSICA AFRICANO RODRIGUEZ[1], MASOUD BARATI[2], PAYMAN DEHGHANIAN[3], AND DAVID FELIPE CELEITA RODRÍGUEZ[4]**

[1]Universidad de los Andes, Bogotá, Colombia
[2]Department of Electrical and Computer Engineering, University of Pittsburgh, Pittsburgh, PA, USA
[3]Department of Electrical and Computer Engineering, The George Washington University, Washington, DC, USA
[4]Faculty of Engineering, Universidad de La Sabana, Chía, Colombia

**ABSTRACT** An electrical network can continue oscillating after a load is restored or a line is reclosed. A later intervention can then resemble the recovery of an earlier one. We address this ambiguity by comparing physical histories from eight sparse PMUs. DAE-derived switched predictors use voltage, oriented terminal current, frequency and ROCOF, start from estimated past states, and preserve recovery through restoration. A ten-second state history supports screened onset proposals; conditional evidence integrates load severity and updates fixed network hypotheses. Active-event and originating-cause masses keep ongoing interventions separate from their remaining response. Completed development streams give 53/54 timely family/source decisions with 4 extra alarms; nominal gains one timely decision at a higher alarm burden. Independent confirmation is in progress. In a separate known-onset load test, conditioned signatures reduce median relative severity error from 1.2% to 0.329%, while matching reference-only source accuracy. The contribution is a specified recovery-aware attribution mechanism and an evaluation separating detection, timely location and restoration. The scope is a known load/line catalog; probability calibration, all-family diagnosis and real-time deployment remain unestablished.

**INDEX TERMS** event detection, model uncertainty, phasor measurement units, physics-informed inference, sequential diagnosis, source localization.

## I. INTRODUCTION

AFTER a load is restored or a line is reclosed, the machines continue moving. A second intervention may begin before that response has decayed. With only eight PMUs in a 39-bus network, a change in a measured signal may therefore indicate a new source, recovery from an earlier source, or an imperfect physical prediction. The task is to distinguish these explanations using only the reports available at the decision time.

Physical restoration is not electrical recovery. A detector that returns immediately to a flat reference can issue another alarm for the remaining oscillation. Suppressing alarms throughout recovery can instead hide a real intervention. The operating point adds another difficulty: correcting a voltage or current offset need not correct how the network responds to a later input.

Existing work provides strong foundations. DAE state estimators infer unmeasured electrical states [1]; physical outage detectors compare network hypotheses sequentially [2], [3]; and simulated fault trajectories support diagnosis from sparse PMUs [4]. Physical models, transient histories and unknown-onset searches are thus established ingredients. A small state-reconstruction error, however, does not by itself identify the intervention that produced the observations.

We compare physical histories rather than isolated signal features. A history specifies an intervention, source, onset, severity and restoration. DAE-derived predictors start from estimated past states and preserve the state left by previous interventions. Conditional evidence integrates load severity, accounts for instrumental memory, and updates fixed network-model hypotheses. Separate active and cause masses keep a restored intervention available as an explanation of the continuing response.

The paper makes three contributions within this restricted problem:

1) An executable attribution mechanism that makes new load/line interventions compete with retained recovery histories. We specify its physical predictors, evidence updates and decision rules.
2) A comparison that separates detection, correct source attribution before restoration, extra alarms and episode closure. Nominal and uncertain network models are





**FIGURE 1. Implemented physical-history attribution, organized into model preparation (A), startup context (B), per-report inference (C), and publication (D). The bank predicts before state correction and saves model evidence before proposal selection. Candidate replay replaces a likelihood suffix, so each report contributes once. The feedback loop retains physical and instrumental memory through restoration. Reserved event truth is used only after predictions are sealed.**

evaluated alongside two fixed ExtraTrees adapters; Chen's published detector is compared on eligible persistent line openings.

3) A controlled IEEE-39 test that separates correction of the pre-event reference from a change in the event signature. The test estimates context from PMUs and measures response fidelity, source decisions and continuous severity.

Completed development streams expose a trade-off: the five-model reference obtains 53/54 timely family/source decisions with 4 extra alarms, while nominal gains one timely decision at a higher alarm burden. The prespecified confirmatory comparison is still running without method changes. The claim is scoped to the declared load/line catalog. These simulations do not establish an all-family hackathon score, calibrated event probabilities or real-time deployment.

## II. RELATED WORK

### A. STATE ESTIMATION AND PHYSICAL SOURCE INFERENCE

Unknown-input and DAE estimators recover electrical states despite incomplete models or exogenous inputs [1], [5], [6]. Functional observability asks whether a requested state quantity can be recovered [7], [8]. Source inference asks which intervention can explain the trajectory. Descriptor-model diagnosability and nuisance-profiled tests formalize this distinction [9], [10].

Physical hypotheses support outage inference from phasor angles [11], Bayesian inference with uncertain states [12], and sequential detection under stochastic operation [2], [3]. Anguluri *et al.* recover sparse forcing locations, inputs and an unknown initial state using group LASSO for linear dynamics [13]. These are precedents for source recovery; group LASSO is not an executed comparator in our frozen campaign. Sensor placement also affects source distinguishability [14]–[16].

### B. TRAJECTORY-BASED AND SEQUENTIAL DIAGNOSIS

Warner *et al.* compare simulated voltage/current fault trajectories over a moving onset window and return candidate lines [4]. Their evaluated target is short-circuit identification before clearing; load changes are an adverse-event test. Our target follows load changes and line openings through restoration and successive interventions. Physical trajectory libraries, remote PMUs and retrospective onset scanning are shared ingredients. Their procedure was not run on our data, so no numerical superiority is inferred.

The Adaptive Matrix CuSum derives sequential identification error/delay results under specified observation laws [17]. Multiple-model filtering already propagates conditional state/mode hypotheses [18]. Our pruned history bank uses these ideas, but its approximate covariances, proposal screen and fitted startup context do not inherit their general guarantees. The difference tested here is how retained recovery competes with a later intervention and affects timely attribution and alarm burden.

### C. LEARNED DIAGNOSIS AND PHYSICAL UNCERTAINTY

Learned and knowledge-driven representations identify PMU disturbances and assets [19]–[21]. We compare two fixed ExtraTrees adapters from the SGSMA project. Their performance tests transfer of those implementations, not the limits of all supervised learning. A known physical catalog and source-excluded supervised training also impose different information constraints.

Physical stochastic models support latent-state estimation [22], [23], while joint DAE parameter inference addresses uncertain generators and networks [24]. Our stream method uses a finite bank of constant network hypotheses. The separate signature test examines a local event–context derivative; it does not identify every plant parameter or replace the stream method with an unrestricted joint estimator.

## III. PROBLEM AND MEASUREMENT MODEL

At report $k$, inference uses measurements through $t_k = k/30$ to decide whether a physical intervention occurred. Detection concerns its presence; classification selects a physical operator; localization selects a bus or branch. These outputs can become reliable at different times. We record the estimated physical onset $\widehat{\tau}$ separately from the alarm and diagnosis emission times.

Figure 2 introduces the broader measurement phenomena using the known RAW0001 reference record. Faults, line changes, generation changes and load changes alter the physical network; missing or corrupted reports alter observation integrity. The present causal test addresses load changes and line openings with restoration. The other panels provide context, not additional validated event classes.

The network has 39 buses, but the prescribed PMU set is

$$\mathcal{P} = \{2, 5, 6, 10, 19, 22, 29, 39\}. \tag{1}$$

Voltage is measured at each PMU bus. Current is measured at a specified branch terminal, which can differ from that bus. The causal implementation uses 47 coordinates: eight voltage magnitudes, eight voltage angles, eight current magnitudes, seven current angles, eight absolute frequencies and eight ROCOFs, at 30 reports/s. BUS39 current angle is excluded because its interpretation remains partially validated. The BUS5 current terminal retains the provisional historical 5–6 assignment. These are declared measurement assumptions, not identities inferred from classification accuracy.

The exported magnitudes are in V and A, angles in degrees, frequency in Hz and ROCOF in Hz/s. Internal centered coordinates do not replace the absolute frequency contract. These are reporting-rate phasor measurements; waveform harmonics or THD are not measured by these channels.

The physical model is

$$\dot{x} = f_q(x, z, u; \theta), \qquad 0 = g_q(x, z, u; \theta), \tag{2}$$

$$y_k = \mathcal{M}_q(x_k, z_k; \theta_M) + b + \varepsilon_k. \tag{3}$$

Here $x$ contains machine and control dynamics, $z$ the algebraic network variables, $q$ the topology/intervention mode, and $\theta_M$ the measurement convention. The measurement map includes gains, phase references, orientation and the causal frequency/ROCOF estimator. A machine's rotor speed is not substituted for bus frequency.

An intervention history is $h = (e, c, \tau, a, \kappa)$: family, source, onset, severity and restoration time, with $\kappa = \infty$ for a sustained event. Its duration is $\kappa - \tau$ when restoration occurs. A load changes its local P/Q setpoints; a line opening switches its branch primitive. For the supported impulse-free switches,

$$x(\tau^+) = x(\tau^-), \qquad g_{q^+}(x(\tau^-), z(\tau^+), u; \theta) = 0. \tag{4}$$

The algebraic voltage/current response may jump even though dynamic states remain continuous. Physical restoration reverses the intervention operator. It does not return the machines to their pre-event state, so electrical recovery can continue after OFF.

The generator stores event schedules and true states separately from the PMU stream. Inference receives the nominal network, permitted calibration and reports through the current time. It receives no source, switch time, true R/X realization or solver state. Initial operating context and noise scale are estimated from 300 startup reports; monitoring begins after the inherited 12-s warmup. The startup contract assumes no intervention in that prefix.

## IV. RECOVERY-AWARE PHYSICAL ATTRIBUTION

Figure 1 describes the implemented computation. The inference engine, archived as R11, uses a conditional history bank of DAE-derived switched state-space predictors. The nonlinear simulator generates observations; inference does not solve a new full nonlinear simulation for every candidate at every report.

Physics enters the candidate dynamics, input directions and oriented measurement map. Statistical filtering represents uncertain states and discrepancy around those predictions. Thus the evaluated method is model-based inference; it does

**TABLE 1. Closest inference contracts. Only Chen and the fixed ExtraTrees adapters are executed comparators in the confirmatory stream campaign. An untested capability is not an algorithmic impossibility.**

| Route | Mechanism | Evaluated target | Role in this study |
|---|---|---|---|
| Chen / Rovatsos | Network likelihoods and sequential tests | Line outages; Rovatsos includes transients | Chen on persistent-line first decisions |
| Warner high-fidelity | Simulated V/I paths and onset search | Short-circuit line candidates | Closest trajectory precedent; no common-data run |
| Adaptive Matrix CuSum | Sequential diagnosis with error/delay analysis | One unknown distributional change | Statistical precedent; no inherited guarantee |
| DAE / stochastic-state estimation | Physical state and uncertainty models | States, unknown inputs or parameters | Components and adjacent tasks |
| Learned PMU diagnosis | Features or constrained representations | Event families and locations | Two frozen ExtraTrees references |
| Physical history bank here | Estimated-past-state paths and recovery | Successive catalog load/line events | Timely attribution, extras and restoration |





**FIGURE 2. Representative signatures from the archived RAW0001 reference simulation: fault, line outage, generation change, load change, missing PMU data and corrupted voltage. Alignment uses retrospective label onset for illustration; inference receives no such alignment. The gray clock in (e) is an illustrative reference, not another measured channel. Only load and line mechanisms enter the causal evaluation below. RAW0001 is known retrospective evidence, not independent field validation.**

not train a neural network with a physics loss or learn a source-label classifier. A good residual fit alone is insufficient: competing histories must also yield a timely source decision.

### *A. CONSTRUCT THE PREDICTOR FROM THE NETWORK*

Kirchhoff constraints and complex power connect sources to remote PMUs:

$$I_{bus} = Y_{bus}V, \quad I_{term,r} = Y_{term,r}V, \quad S_i = V_i I^*_{bus,i}. \tag{5}$$

Terminal rows retain orientation, line charging and transformer ratios. A measured terminal current is not a nodal injection. A line opening changes its branch primitive and terminal map; a load changes its admitted P/Q input direction.

On a regular index-one DAE chart with a fixed angle reference,

$$\begin{aligned} \delta z &= -g_z^{-1}(g_x \delta x + g_u \delta u), \\ \delta \dot{x} &= A_q^{red}\delta x + B_q^{red}\delta u, \\ A_q^{red} &= f_x - f_z g_z^{-1} g_x, \quad B_q^{red} = f_u - f_z g_z^{-1} g_u. \end{aligned} \tag{6}$$

Observation derivatives provide the corresponding reduced output. The implementation discretizes these operators for the admitted switch modes. Inertia, controls and load law remain those of the fixed plant.





**FIGURE 3.** **IEEE 39-bus single-line diagram: 46 branches, 12 transformers and 10 generators. Blue bars and P marks locate the eight voltage PMUs. Orange branches and load arrows identify the nine line and nine load candidates; gray arrows denote other loads. Current terminals follow the separate measurement contract. All routes are orthogonal.**

**TABLE 2.** **Scope of the executed causal component. The source is an intervention asset; it is not necessarily a measured PMU bus.**

| Case | Physical operator | Executed claim |
|---|---|---|
| Normal | No intervention | Monitor after startup |
| Load | Local P/Q factor; optional restoration | Nine candidate buses |
| Line | Branch open; optional reclose | Nine candidate branches |
| Fault/generation | Different shunt/input/trip operators | Outside this causal test |
| Missing/bad data | Measurement-integrity mechanism | Outside C01 |
| Unknown | Unresolved diagnosis | Not a new physical family |

After augmenting instrumental memory, a conditional predictor has the local form

$$\begin{aligned} \xi_{k+1} &= A_{\ell,q}\xi_k + b_{\ell,q} + B_{\ell,q}a + w_k, \\ r_k &= C_{\ell,q}\xi_k + d_{\ell,q} + D_{\ell,q}a + v_k. \end{aligned} \tag{7}$$

Here $r_k$ contains reference-corrected, scaled and instrument-whitened PMU coordinates, $\ell$ is a fixed network hypothesis, and $\xi_k$ contains physical deviation states, phase history and predicted measurement-filter memory. Observed colored-instrument filters whiten measurements; their corresponding predictor memory is deterministic. Additional latent AR states represent persistent discrepancy, with preset quiet/load/line/recovery covariance and drift regimes. This statistical discrepancy model is distinct from the plant equations. $v_k$ denotes the remaining innovation. A load has scalar severity within its specified P/Q direction. A line uses a switched operator rather than a fictitious load-amplitude fit. States from different equilibria are not interpreted as an absolute rotor-state mixture.

### B. ESTIMATE CONTEXT FROM THE STARTUP PREFIX

Each network hypothesis uses the same 300 startup reports to estimate operating factors, reference phase and noise scale. Voltage/current coordinates receive a constant discrepancy correction,

$$\widehat{b}_\ell = \bar{y}_{0:299} - y_\ell^{ref}, \qquad b_{\ell,k} = \widehat{b}_\ell \quad (k \geq 300). \tag{8}$$

Angular differences respect wrapping and the common reference. Frequency and ROCOF use empirical prefix centers. The correction remains fixed so it cannot track a later load step and subtract its signature. This estimates an observation discrepancy, not the true impedances. Prefix estimates enter by substitution rather than through a full joint parameter posterior.

### C. COMPARE UNKNOWN-ONSET HISTORIES

The method retains ten seconds of past conditional states. Its frozen birth screen searches lags of 0–18 reports and proposes selected onsets; it does not enumerate every onset in the 300-report history. Each history specifies family, asset, onset, restoration mode and severity. It starts from the stored conditional state before its proposed onset. That state already contains any ongoing recovery; an alarm does not reset the predictor to equilibrium.

For a retained load history, conditional Gaussian filtering yields a residual $e$, severity response $s$ and covariance $S$. Unknown severity has a truncated-Gaussian distribution inherited from previous reports:

$$L_{h,k} = \int_l^u \mathcal{N}(e; sa, S)\, \mathrm{TN}_{[l,u]}(a; \mu, v)\, da. \tag{9}$$

With $\Phi$ denoting the standard normal CDF, define

$$\begin{aligned} v' &= (v^{-1} + s^\top S^{-1} s)^{-1}, \\ \mu' &= v'(\mu/v + s^\top S^{-1} e), \\ Z(\mu, v) &= \Phi((u-\mu)/\sqrt{v}) - \Phi((l-\mu)/\sqrt{v}). \end{aligned} \tag{10}$$

The implemented local integral follows by completing the square:

$$\begin{aligned} \log L_{h,k} = \log \mathcal{N}(e; 0, S) + \tfrac{1}{2}\log(v'/v) \\ + \tfrac{1}{2}(\mu'^2/v' - \mu^2/v) + \log \frac{Z(\mu', v')}{Z(\mu, v)}. \end{aligned} \tag{11}$$

These standard identities are exact for the stated local conditional model. Adaptive proposals, pruning and covariance approximations make the complete bank approximate.

The rolling screen proposes histories; it is not another independent observation. Replaying a suffix replaces its original no-new-event suffix likelihood. The sequential update therefore counts each report once, rather than repeatedly accumulating overlapping ten-second windows.





**FIGURE 4. Simulated observations supplied to inference. One fixed development parent provides a load and a line example at all eight PMUs. Shading marks physical ON–OFF for evaluation only. Magnitude changes use the local pre-event center; frequency is centered for display while its exported channel remains absolute Hz. Source, severity and operating context affect the curves, so they are not universal class templates.**

### *D. REPRESENT FIXED NETWORK UNCERTAINTY*

The bank contains nominal, global $\pm 2\%$, and selected-branch $\pm 3\%$ paired R/X hypotheses. Parameters stay constant within a hypothesis. Its outer weight uses a predictive density formed before the current-report state update and proposal selection:

$$w_{\ell,k} = \frac{w_{\ell,k-1} p_\ell(y_k \mid \mathcal{F}_{k-1}, \widehat{b}_\ell)}{\sum_j w_{j,k-1} p_j(y_k \mid \mathcal{F}_{k-1}, \widehat{b}_j)}. \tag{12}$$

Startup-fitting reports are not scored again as independent model-selection evidence. The mixture covers a finite set of network alternatives rather than identifying a continuous impedance posterior.

### *E. KEEP RECOVERY AS A COMPETING PHYSICAL EXPLANATION*

Restoring an input or topology at $\kappa$ does not restore the pre-event state: $x(\kappa^+) = x(\kappa^-)$. On a regular local post-restoration chart, the difference from a same-context no-new-intervention trajectory obeys

$$\begin{aligned} \delta x_h(t) &\simeq \Phi_0(t,\kappa)\delta x_h(\kappa), \\ \delta y_h^{net}(t) &\simeq C_0(t)\Phi_0(t,\kappa)\delta x_h(\kappa), \quad t > \kappa. \end{aligned} \tag{13}$$

Here $y^{net}$ denotes voltage/current coordinates before the instrument map. Instrumental memory is retained as well. This local interpretation of known dynamics explains why the reference after OFF is a trajectory, not a zero residual; it is not a new propagation theorem.

For conditional history mass $\pi_{\ell,h,k}$, define active and originating-cause masses for an admissible family/source cell $c$:

$$\begin{aligned} M_{c,k} &= \sum_\ell w_{\ell,k} \sum_{h:c(h)=c} \pi_{\ell,h,k}\, \mathbf{1}\{h \text{ active at } k\}, \\ \Gamma_{c,k} &= \sum_\ell w_{\ell,k} \sum_{h:c(h)=c} \pi_{\ell,h,k}. \end{aligned} \tag{14}$$

A retained history can stop being active while its cause still explains recovery. Later interventions compete with those

histories. The implementation stores 18 admissible cells, not every family at every bus.

Writing the conditional active mass as $M_{\ell,c,k}$ yields

$$\Delta M_{c,k} = \sum_{\ell} w_{\ell,k}(M_{\ell,c,k} - M_{\ell,c,k-1}) + \sum_{\ell}(w_{\ell,k} - w_{\ell,k-1})M_{\ell,c,k-1}. \quad (15)$$

The terms distinguish within-model evolution from model reweighting. This accounting identity aids interpretation, without constituting a new tensor factorization. The masses are approximate attribution weights; probability calibration and globally optimal filtering are not established.

### F. EMIT SEPARATE DETECTION, DIAGNOSIS AND RESTORATION MESSAGES

The fixed publication rules require active mass 0.99 for six reports to confirm an alarm, and restoration mass 0.99 for 15 reports to confirm OFF. The archived source/line confirmation and episode-replacement rules determine the public diagnosis. Every message records emission time and the last report used. A diagnosis can be correct eventually but too late to precede physical OFF.

The nominal comparator uses the same nominal conditional model with its own fixed publication path. Comparing nominal and mixture tests the outer network bank. The admission-rule ablation tests a different publication decision; it is not a pure recovery-memory ablation.

### G. PER-REPORT ALGORITHM AND COMPUTATIONAL BOUNDARY

**Algorithm 1: causal physical-history attribution.** The inputs are the nominal model, fixed method configuration and successive PMU reports. Reserved event truth never enters these steps.

1) Estimate operating context, common reference and noise scale from the startup prefix. Initialize conditional states and retain the eligible past states needed by retrospective proposals.
2) At report $k$, apply the frozen centering, scaling and instrumental transformation. Propagate each retained physical/recovery history and its conditional uncertainty to predict this report.
3) Apply the frozen short-lag birth screen using retained past states. A proposed history starts before its selected onset; replay replaces the corresponding likelihood suffix rather than adding it twice.
4) Score the report using its predictive density, before correcting the state with that report. Integrate the allowed load severity and apply the archived switched operator for a line hypothesis.
5) Correct the conditional states and severity distributions; update network weights and the retained history bank using the fixed rules. Preserve dynamic state and originating cause through restoration.
6) Aggregate active mass $M$, cause mass $\Gamma$ and $\Delta M$. Apply the fixed alarm, diagnosis and OFF-publication rules. Store emission time, estimated onset, family/source and the last report used.

The nonlinear simulator constructs observations; this algorithm propagates local switched predictors. The input grid is 30 reports/s. Causality concerns report availability; acquisition throughput, computation time and the electrical history needed for a decision are separate quantities. Wall-clock real-time operation has not been established.

## V. EXPERIMENTAL DESIGN

The primary experiment asks whether the causal bank can attribute successive load/line interventions without confusing recovery with a new event. Development, independent evaluation and an auxiliary source-resolution experiment answer different questions and retain separate denominators.

The simulator is the IEEE-39 Julia/PowerDynamics research candidate F01. Each physical parent is integrated continuously, preserving differential states through ON/OFF. Its PMU reporting grid is separate from solver steps: a 120-s record contains 3601 reports per PMU and a 600-s normal record contains 18001, including endpoints. At a switch-aligned report the export uses the post-switch algebraic value. Measurement references, load law and stochastic instrument parameters are fixed across events. RAW0001 supplied retrospective calibration context, not independent test data.

H03 and H04 each contain three event parents with six successive load/line interventions and one normal parent, all 80 s long. Schedules are paired across nominal, in-bank R/X and mixed out-of-bank R/X conditions. Each campaign therefore has 18 unique interventions and 54 event realizations. Both campaigns are now development evidence. No interval or generalization claim treats those 54 realizations as independent events.

R11 and its nominal version are frozen co-references. Both ExtraTrees artifacts and their causal preprocessing/publication adapters are frozen as well; neither is retrained on H04 or C01. They receive the same 30-fps observations. This is a comparison of those operational implementations on the stated contract, not a rerun of the hackathon leaderboard.

The published physical comparator is Chen *et al.*'s persistent single-line quickest-change detector [2]. Its reduced-network covariance is marginalized to the observed PMU subset after inversion. Parallel CUSUM statistics stop at the first threshold crossing and select a line. Our declared F01 adapter uses nonoverlapping angle increments at 15 Hz, a startup-only scale/drift estimate and the fixed nominal line catalog. Its white-injection/DC assumptions do not describe all F01 instrumental effects. We preserve both matched-law implementation checks and F01 mismatch failures; no ARL guarantee is transferred to colored noise.

The eligible common test for Chen is one persistent line opening or a normal record. Its output has no load family or restoration operator. The independent campaign, C01, there-

**TABLE 3. Experimental populations and their purposes. Conditions and noise realizations repeat a physical parent rather than creating independent trajectories.**

| Population | Configuration | Main outcome | Interpretation |
|---|---|---|---|
| Continuous development | Three event parents, six interventions each; one normal parent; three network conditions | Timely family/source, extras and restoration | Open development evidence, not independent confirmation |
| Independent continuous evaluation | 18 event parents, six interventions each; 12 normal parents; three network conditions and two noise scales | Paired attribution, false alarms, delays and failures | Prespecified comparison of unchanged methods |
| Persistent-line evaluation | Nine lines, three parent repetitions; same network/noise strata | First stopping decision, source and censoring | Eligible comparison with published line-outage QCD |
| Signature component test | 57 dictionary and 85 test trajectories; four loads; three common noise seeds | Nominal, reference correction and mixed-signature correction | Known ON/OFF and family; separate from causal accuracy |

fore separates continuous load/line episodes from persistent-line first-stop decisions. Early stops, wrong sources, omissions and horizon censoring remain visible.

For continuous events, an alarm is associated temporally before predicted family/source is inspected. The first unmatched alarm after ON is eligible up to the next ON, with the inherited 30-s cap. A timely joint decision requires the correct family and asset emitted before true OFF. Unmatched alarms are extras; false restorations and open episodes are reported separately. These definitions prevent an eventual correct answer from hiding a late diagnosis.

C01 specifies 18 continuous parents, 27 persistent-line parents and 12 normal parents, with three R/X conditions and instrumental-noise scales of one and two. The 171 intended physical trajectories yield 342 observed records. Conditions represent nominal parameters, perturbations represented in the bank and mixed perturbations outside it. Solver and inference failures remain in the intended denominators. Comparisons use 10,000 paired parent-cluster resamples; repeated conditions/noise do not count as independent parents. Predictions are fixed before the evaluator opens reserved truth.

Logical decision delay is measured on report timestamps. Wall-clock cost is recorded separately with hardware, process concurrency and one-thread BLAS settings; parallel execution of independent records does not make a within-record inference method real-time. The independent evaluation is in progress. The following section reports completed development results only.

## VI. CONTINUOUS-STREAM RESULTS

### A. TIMELY ATTRIBUTION AND EXTRA ALARMS MEASURE DIFFERENT OUTCOMES

In H04, both ExtraTrees adapters and both physical references identify all tested lines in time (Table 4). The difference is in loads: the five-model bank obtains 26/27 timely decisions, nominal 27/27, and these ExtraTrees adapters 0/27. This tests transfer of the frozen adapters; it neither rules out supervised load detection nor reproduces the historical multi-class hackathon score.

**TABLE 4. What the causal component actually resolves in H04 development. Load and line columns require the correct family and source emitted before OFF. The 54 realizations repeat 18 interventions across three R/X conditions; they are not 54 independent trials. Normal exposure is only 204 s per method.**

| Method | Load timely | Line timely | Extras | Normal alarms |
|---|---|---|---|---|
| Physical (5 models) | 26/27 | 27/27 | 4 | 0 |
| Physical nominal | 27/27 | 27/27 | 7 | 0 |
| ExtraTrees ref. | 0/27 | 27/27 | 3 | 0 |
| ET short | 0/27 | 27/27 | 3 | 0 |
| Onset witness | 25/27 | 27/27 | 0 | 0 |

The five-model bank detects and eventually attributes 54/54 realizations, but only 53 diagnoses precede physical OFF. Nominal has 54 timely diagnoses, with 7 extras versus 4. Detection, eventual attribution and timely attribution therefore give different answers. Representing model uncertainty trades an additional late diagnosis for fewer extra alarms here.

### B. RECOVERY AND A NEW EVENT MUST REMAIN COMPETING EXPLANATIONS

Figure 6 shows what the counts omit. The physical state continues evolving after OFF. Retained cause/recovery histories explain that trajectory without resetting the network; a later source must compete against both no-new-event recovery and other interventions.

The out-of-bank BUS31 case shows a remaining timing failure: the source is recovered eventually but too late. The network mixture changes how much mass is assigned to that source, and (15) separates that revision from within-model evidence. This is what the array adds to the explanation. The figure does not establish that a tensor representation alone improves accuracy.

The onset-witness ablation obtains zero extras but only 52/54 timely attributions: weak early evidence rejects a real BUS16 load. It inherits the physical states and masses, so suppressing the alarm does not repair the underlying explanation. This negative experiment leaves R11 and nominal frozen for





**FIGURE 5.** **The decision that an accuracy-only table hides. H04 development outcomes trade timely attribution against unmatched event-stream alarms. The onset-witness ablation removes all extras but loses a real BUS16 intervention; it is retained as negative evidence. Labels use 54 paired realizations of 18 interventions and do not imply 54 independent trials.**

C01.





**FIGURE 6.** **From a continuous sequence to source attribution. Top: reserved physical ON–OFF intervals in development parent H002. Middle: active masses for nominal-network observations (MATCH) and mixed R/X changes outside the bank (OUT SUPPORT). Orange dotted lines mark true OFF for evaluation only. Bottom: BUS31 in the latter record; the cumulative terms of $\acute{M}$, rebased at 34 s, sum to the change in active mass. Diagnosis arrives after OFF. The figure shows an eventual correct source that fails timely attribution; the color scale represents approximate mass, not calibrated probability.**

## VII. OPERATING-POINT SIGNATURE EXPERIMENT

### A. REFERENCE CORRECTION AND RESPONSE CORRECTION

The stream bank already builds local predictors at estimated operating points. A separate experiment tests why changing a reference alone may be insufficient. It compares three response approximations with identical observations, channels, timing, amplitude prior and inference horizon. It is a controlled test of a mixed derivative, not another version of R11.

Let $\eta$ denote a scalar operating change and $a$ the signed load factor. Central differences of complete nonlinear DAE trajectories give

$$D_i(\eta) \simeq \frac{y_i(\eta, h) - y_i(\eta, -h)}{2h},$$
$$E_i \simeq \frac{D_i(d) - D_i(-d)}{2d}. \tag{16}$$

The event follows the same ON/OFF schedule in every derivative trajectory. The fixed $Q_i^0$ is the coefficient of $a^2$, obtained from the centered second difference divided by $2h^2$. After removing the frozen common angle drift, the three predicted histories are

$$\mu_i^{\mathrm{N}}(a) = y_0 + aD_i^0 + a^2 Q_i^0,$$
$$\mu_i^{\mathrm{R}}(a) = \mu_i^{\mathrm{N}}(a) + \widehat{b},$$
$$\mu_i^{\mathrm{E}}(a) = \mu_i^{\mathrm{R}}(a) + a\widehat{\eta}E_i. \tag{17}$$

Both corrected variants use exactly the same prefix offset $\widehat{b}$. This comparator corrects the measured PMU reference; it is not the separate nonlinear AC hidden-state reconstruction algorithm in the historical study. Only the last changes the event signature. The first two consequently have identical incremental response models even when their absolute fits differ. Context $\widehat{\eta}$ is estimated by generalized least squares from the pre-event PMUs and the nominal context direction. No test context, source or severity enters inference.

### B. TEST CASES AND DECISION CONTRACT

The frozen F01 plant supplies all trajectories. The scalar $\eta$ scales PQ operating injections and active PV dispatch; feasible initialization can change permitted operating setpoints, but not machine constants, line impedances, ZIP fractions or the PMU model. Central event/context steps are 0.005 and 0.01, with step-halving checks. Dictionary construction uses 57 trajectories. The test contains 85 physical cases: 80 load interventions and 5 controls at operating changes $-3\%, -2\%, 0, +2\%, +3\%$. Each load changes P/Q together by $\pm 0.1\%$ or $\pm 1\%$ at BUS3, BUS7, BUS16 or BUS24. None belongs to the prescribed voltage-measurement PMU set; the separate oriented current-terminal assignments remain fixed.

Each case is one ten-second integration, with ON at 3 s, OFF at 6 s and no state reset. The context fit ends at 2.5 s. Three frozen instrumental noise seeds produce 255 paired records. The nonlinear PMU frequency/ROCOF operator runs before its archived instrumental noise is added. Both corrected methods retain the same measured prefix, so an advantage cannot arise from supplying one method a better initial reference.

This experiment supplies the load family and ON/OFF times. It estimates source and continuous severity using the same bounded Gaussian prior and amplitude-integrated likelihood in all three variants. The no-event hypothesis is retained. The fixed colored-instrument transform is common; plug-in prefix estimates and clipped noise still limit probability calibration. Thus these decisions are not unknown-onset detector scores and normal-window decisions are not continuous false-alarm rates.

### C. RESPONSE ERROR AND SOURCE DECISIONS

Relative to recentering alone, the mixed term reduces mean incremental response error: the paired difference is -1.15 percentage points (95% interval [-1.31, -1]). The corresponding joint-decision difference is 0 percentage points ([0, 0]), which does not establish a directional improvement in joint source decisions. The recentered and conditioned source decisions are already at the test ceiling. Median absolute relative severity error, evaluated at the generating source, changes from 1.2% to 0.329%. Its mean paired change is -0.738 percentage points ([-0.898, -0.582]). Both variants select the correct source in every tested event record, so this severity comparison does not discard source errors. Their source masses numerically saturate at one; zero recorded log-loss is not evidence of calibrated uncertainty.

The gain is not uniform across all comparisons: at the nominal operating point, estimating an unnecessary reference/context can worsen severity relative to keeping the correct fixed reference. Figure 8 retains that case rather than reporting only shifted operation.

The derivative stability checks change $E_i$ by 0.283–0.427% when the context step is halved. Halving the event step in the two checked directions changes it by at most 0.00977%. These are local numerical checks, not a global smoothness or identifiability certificate. Percentages of event severity refer to the P/Q input factors; actual load power also responds to voltage under the frozen impedance law.

Paired intervals resample physical test cases, keeping their noise seeds and methods together. The same three noise seeds are reused across cases; these intervals describe case variation conditional on those common noise realizations, not uncertainty over a noise population or transfer to arbitrary sources or plants. The step-halving checks and all case outcomes remain in the frozen artifact package. Better fidelity, if observed, is not sufficient to establish calibrated source probabilities, all-family diagnosis or a benefit in the unchanged causal campaign.

## VIII. INTERPRETATION AND LIMITS

### A. RESPONSE FIT, SEVERITY AND SOURCE IDENTITY

A better physical prediction need not produce a better location. Competing sources may remain similar after their severities and initial conditions are fitted. For a response $s_h$





**FIGURE 7.** Executed signature ablation, separate from the stream algorithm in Fig. 1. The three variants share the data and decision calculation; only reference and event-response terms differ.

**TABLE 5.** Controlled signature test, separate from causal detection. Response error is the median whitened incremental error at the generating source/severity over 80 physical cases. Joint correctness includes presence and source on 240 noisy event records; source-only ranking conditions on a load. Severity error is median absolute relative error at the generating source. Normal selections use 15 fixed windows, not normal-hours exposure.

| Model | Response error (%) | Joint correct | Source-only correct | Normal event selections | Severity error (%) |
|---|---|---|---|---|---|
| Nominal | 1.25 | 114/240 | 114/240 | 12/15 | 3.45 |
| Recentered | 1.25 | 240/240 | 240/240 | 0/15 | 1.2 |
| Conditioned | 0.0561 | 240/240 | 240/240 | 0/15 | 0.329 |





**FIGURE 8.** Separate effects of recentering and conditioning. (a) Incremental response error in the fixed physical test cases, evaluated at the generating source and severity to isolate approximation error. (b) Correct source and presence decisions on noisy observations, after marginalizing severity. (c) Relative severity error evaluated at the generating source. The panels measure different outcomes. Noise realizations repeat physical cases and are not counted as additional independent trajectories. Nominal and recentered incremental predictions coincide.

at specified severity and context, the distance to an admitted competitor is

$$d_h^2 = \min_{j \neq h} \min_{\beta_j \in \mathcal{A}_j} \|s_h - s_j(\beta_j)\|^2_{\Sigma^{-1}}. \tag{18}$$

The set $\mathcal{A}_j$ fixes allowed signs, severities and nuisance coordinates. Small distance makes source discrimination noise-sensitive; it is not a universal error formula or a calibrated decision certificate [9], [10].

Three outcomes remain separate: prediction error at a specified physical source, ranking of competing sources, and uncertainty calibration. A response improvement establishes the first. It establishes the second only if source decisions improve under the same observations, horizon and decision rule. Neither establishes the third automatically. A nonlinear response comparison is needed before treating a surrogate's residual confusion as an unavoidable physical limit.

The supplementary archive retains the earlier state-reconstruction and simultaneous-load studies, with their separate observation contracts and prior-normalization qualification. Their known-onset scores are not combined with the causal results here. In particular, recovering hidden voltages





**FIGURE 9.** **Fixed illustrative test: BUS7, $\eta = +3\%$, load factor +1%, seed 390502. Gray traces are the delivered PMU observations. Colored curves use each method's selected source and estimated severity; a no-event selection keeps its baseline. The dotted black curve is physical truth, used only for illustration. The plotted channels and case were fixed without selecting the largest improvement. Shading marks physical ON/OFF for evaluation.**

does not certify the source that moved them.

To first order, a component of the context derivative parallel to a nominal source signature can be absorbed by fitting a different severity. Correct source ranking can therefore coexist with biased intensity. Components orthogonal to that signature cannot be removed by this rescaling. This explains why source accuracy can reach a test ceiling while response and severity errors still distinguish the models; it is a standard projection argument, not a new identifiability theorem.

### *B. OPERATIONAL MEANING AND SCOPE*

The physical distinction underlying the stream method is simple: restoration changes an input or topology, but does not erase the machine state. Retaining that state lets recovery compete with a new intervention. The development comparison also shows why alarm count and timely location must be reported together. Stricter admission can suppress extras while rejecting a real load. The existing admission ablation does not isolate the contribution of every recovery-memory operation.

The signature experiment addresses a different source of error. Its corrected variants receive the same pre-event measurements and offset. Any difference between them therefore comes from the event–context term and its estimated context, rather than a privileged baseline or longer window. This isolates the tested response approximation, but not an improvement of the unchanged causal detector. Known timing, one scalar context and four load sources make it a controlled component test.

Our construction builds on trajectory-based diagnosis, sequential likelihoods and multiple-model filtering. Their general principles are not new contributions here. The methodological claim concerns the specified competition among intervention and recovery histories; the experiments measure its operational behavior. Numerical superiority is claimed only where a common-data comparison supports it, not over Warner or other procedures that were not executed.

The continuous catalog contains nine load buses and nine lines and requires an intervention-free startup. Missing PMUs, unknown families, source-excluded causal transfer and field operation are untested. F01 retains a provisional BUS5 current terminal and excludes BUS39 current angle. Agreement with this research model does not establish the producer's CT placement or exact reproduction of RAW0001. Local predictors, history pruning, covariance approximations and fitted startup parameters also limit probability claims.

F01's noise port applies temporal and cross-PMU structure within each signal family. Its archived cross-family factor covariance is not applied, and frequency/ROCOF noise is added after phase estimation. The inference comparison therefore concerns this declared simulator, not the complete dependence structure of a physical PMU installation.

The two ExtraTrees adapters are particular frozen implementations. Their load-transfer failure does not rule out

learned load diagnosis or establish a better official hackathon score. Chen's eligible test concerns persistent line openings; its F01 adapter has DC/white-injection assumptions that do not capture all instrumental effects. Its mismatches and censored decisions remain part of the comparison.

A further extension would integrate a vector of pre-event context uncertainties rather than substituting a point estimate. A local Gaussian approximation gives

$$V_h(a) = \Sigma_W + J_{\eta,h}(a) P_{\eta,\tau} J_{\eta,h}(a)^\top. \tag{19}$$

Its determinant belongs in the likelihood. The covariance must be calibrated without absorbing the response directions that distinguish sources. Neither the stream scores nor the signature test validate this joint extension, an unrestricted multi-source estimator or an optimal filter. Those questions require their own fixed comparisons.

Finally, processing reports causally is not proof of real-time throughput. Observation time, computation and queue delay must be measured separately. The present implementations remain research inference services rather than validated protection or control systems.

## IX. CONCLUSION

We formulated sparse-PMU event attribution through competing physical histories. Load/line predictors start from estimated past states and retain the cause of the response after restoration. Active mass $M$ and its increment $\Delta M$ expose the changing explanation rather than replacing the physical dynamics.

In completed development streams, the mixture obtains 53/54 timely family/source decisions with 4 extra alarms. Nominal gains one timely decision at a higher alarm burden. Independent confirmation remains in progress.

The controlled load test distinguishes reference correction from signature conditioning. The mixed term reduces response error and median relative severity error, but does not establish a directional improvement in joint source decisions. This component result does not change the frozen causal method.

The result is a specified physical attribution procedure and a testable separation of recovery, reference error and source discrimination. Its scope remains the declared simulation contracts. It does not establish all-family diagnosis, universal source recovery, calibrated probabilities or real-time deployment.

## ACKNOWLEDGMENT

OpenAI Codex assisted with drafting and restructuring the main text, LaTeX preparation, and plotting and execution-infrastructure code. The authors retain responsibility for the scientific content, verification, and final submission.

## REFERENCES

[1] M. Katanic, J. Lygeros, and G. Hug, "Recursive dynamic state estimation for power systems with an incomplete nonlinear DAE model," *IET Generation, Transmission & Distribution*, vol. 18, no. 22, pp. 3657–3668, 2024.

[2] Y. C. Chen, T. Banerjee, A. D. Domínguez-García, and V. V. Veeravalli, "Quickest line outage detection and identification," *IEEE Transactions on Power Systems*, vol. 31, no. 1, pp. 749–758, 2016.

[3] G. Rovatsos, X. Jiang, A. D. Domínguez-García, and V. V. Veeravalli, "Statistical power system line outage detection under transient dynamics," *IEEE Transactions on Signal Processing*, vol. 65, no. 11, pp. 2787–2797, 2017.

[4] A. Warner, D. Hamilton, G. Fellouris, and D. Aliprantis, "Quick line fault detection and identification using high-fidelity models of transient dynamics," TechRxiv preprint, version 1, 2023, posted June 16, 2023; cited as a preprint.

[5] S. Gillijns and B. D. Moor, "Unbiased minimum-variance input and state estimation for linear discrete-time systems," *Automatica*, vol. 43, no. 1, pp. 111–116, 2007.

[6] S. A. Nugroho, A. F. Taha, N. Gatsis, and J. Zhao, "Observers for differential algebraic equation models of power networks: Jointly estimating dynamic and algebraic states," *IEEE Transactions on Control of Network Systems*, vol. 9, no. 3, pp. 1531–1543, 2022.

[7] T. L. Fernando, H. M. Trinh, and L. Jennings, "Functional observability and the design of minimum order linear functional observers," *IEEE Transactions on Automatic Control*, vol. 55, no. 5, pp. 1268–1273, 2010.

[8] A. N. Montanari, L. Freitas, D. Proverbio, and J. Gonçalves, "Functional observability and subspace reconstruction in nonlinear systems," *Physical Review Research*, vol. 4, no. 4, p. 043195, 2022.

[9] D. Eriksson, E. Frisk, and M. Krysander, "A method for quantitative fault diagnosability analysis of stochastic linear descriptor models," *Automatica*, vol. 49, no. 6, pp. 1591–1600, 2013.

[10] L. L. Scharf and B. Friedlander, "Matched subspace detectors," *IEEE Transactions on Signal Processing*, vol. 42, no. 8, pp. 2146–2157, 1994.

[11] J. E. Tate and T. J. Overbye, "Line outage detection using phasor angle measurements," *IEEE Transactions on Power Systems*, vol. 23, no. 4, pp. 1644–1652, 2008.

[12] Y. Zhao, J. Chen, A. Goldsmith, and H. V. Poor, "Identification of outages in power systems with uncertain states and optimal sensor locations," *IEEE Journal of Selected Topics in Signal Processing*, vol. 8, no. 6, pp. 1140–1153, 2014.

[13] R. Anguluri, O. Kosut, and L. Sankar, "Localization and estimation of unknown forced inputs: A group LASSO approach," *IEEE Transactions on Control of Network Systems*, vol. 10, no. 4, pp. 1997–2009, 2023.

[14] M. Jamei, R. Ramakrishna, T. Tesfay, R. Gentz, C. Roberts, A. Scaglione, and S. Peisert, "Phasor measurement units optimal placement and performance limits for fault localization," *IEEE Journal on Selected Areas in Communications*, vol. 38, no. 1, pp. 180–192, 2020.

[15] F. Conte, F. D'Agostino, B. Gabriele, G.-P. Schiapparelli, and F. Silvestro, "Fault detection and localization in active distribution networks using optimally placed phasor measurements units," *IEEE Transactions on Power Systems*, vol. 38, no. 1, pp. 714–727, 2023.

[16] T. Yildiz and A. Abur, "Sparse PMU placement algorithm for enhanced detection and identification of power grid events," *IEEE Transactions on Power Systems*, vol. 40, no. 2, pp. 1843–1853, 2025.

[17] A. Warner and G. Fellouris, "Sequential change diagnosis revisited and the adaptive matrix CuSum," *Bernoulli*, vol. 30, no. 3, pp. 2228–2252, 2024.

[18] H. A. P. Blom and Y. Bar-Shalom, "The interacting multiple model algorithm for systems with markovian switching coefficients," *IEEE Transactions on Automatic Control*, vol. 33, no. 8, pp. 780–783, 1988.

[19] S. Pandey, A. K. Srivastava, and B. G. Amidan, "A real time event detection, classification and localization using synchrophasor data," *IEEE Transactions on Power Systems*, vol. 35, no. 6, pp. 4421–4431, 2020.

[20] Z. Li, J. Tian, and H. Liu, "A joint data and knowledge-driven method for power system disturbance localisation," *IET Generation, Transmission & Distribution*, vol. 18, no. 24, pp. 4078–4089, 2024.

[21] T. Yildiz and A. Abur, "Convolutional neural network-assisted fault detection and location using few PMUs," *Electric Power Systems Research*, vol. 235, p. 110705, 2024.

[22] M. Ensaf and M. Barati, "Harnessing kernel regression for stochastic state estimation in solar-integrated power grids," arXiv preprint arXiv:2309.10200, 2023, version 1. [Online]. Available: https://arxiv.org/abs/2309.10200

[23] A. M. Tartakovsky, T. Ma, D. A. Barajas-Solano, and R. Tipireddy, "Physics-informed gaussian process regression for states estimation and forecasting in power grids," *International Journal of Forecasting*, vol. 39, no. 2, pp. 967–980, 2023.

[24] A. Alalem Albustami, A. F. Taha, and S. Mahadevan, "DAE-aware bayesian inference for joint generator-network parameter estimation,"

arXiv preprint arXiv:2604.15686, 2026, preprint. [Online]. Available: https://arxiv.org/abs/2604.15686