THE PROBLEM A PMU change after a switch has competing explanations

Recovery

Earlier event is OFF; machines still move

New intervention

Load or line changes during that recovery

Model error

True R/X can differ from the predictor

AT EACH REPORT

Observe

8 PMUs: V, terminal I, f and ROCOF

→

Propose histories

No new event, load, line; retain past states

→

Predict

Switched DAE + PMU map under fixed R/X models

→

Compare

Evidence and state update

→

Publish

Alarm, source, OFF or wait

10 s of past states; onsets proposed over the latest 18 reports

State and cause retained after physical OFF

Reserved event truth enters only the later evaluation.