



Murphy—PFFS—SPOOL—BOM							
Mark	Qty	Description	End 1	End 2	Lft	LDec	Size
1	3	Std Wt SA234 WPB CS BW LR 90 Deg El					4
2	1	Sch 40 SA-53B CS Smls Pipe PE	BEV	BEV	4'-5 3/4"	53.750	4
3	1	Sch 40 SA-53B CS Smls Pipe PE	BEV	BEV	7'-2 11/16"	86.662	4

MURPHY
SINCE 1907

CONSTRUCTORS • ENGINEERS MECHANICAL • INDUSTRIAL

1233 N. Price Rd.
St. Louis, MO 63132-2303
314-997-6600 phone
BIMCAD@murphy-stl.com

DRN JMM CHK APP JOB NO. 210140 REF.DWG. DRAWING NO./TRACKING NO. 210140-A-UPL2-125	WUSM RESEARCH BUILDING				QA/QC ACCEPT				<input type="checkbox"/> FLANGE WEIGHT/ORIENTATION						
	NRB CUP				<input type="checkbox"/> FITTING ORIENTATION				<input type="checkbox"/> BOLTS/CPLG'S/TH'D TIGHT						
	LVLO2 SPOOLS								<input type="checkbox"/> SPOOL IDENTIFICATION						
	SERVICE NAME CH #4 VENT								COMMENTS						
	QTY. 1				SHT/NO 1 of 1				REV 0						
REV 0				REV 0				REV 0				REV 0			
DESCRIPTION				DATE				REV				APP			
DRN				CHK				APP				APP			