



Murphy-PFFS-SPOOL-BOM

Mark	Qty	Description	End 1	End 2	Lft	LDec	Size
4	1	Sch 40 SA-53B CS ERW Pipe Saddle			6"	6.000	14x6
7	1	Sch 40 SA-53B CS ERW Pipe Saddle			6"	6.000	14x10
5	1	150lb RF Sch 40 Bore SA105 CS WN Flg					6
9	1	150lb RF Sch 40 Bore SA105 CS WN Flg					10
1	1	150lb RF Sch 40 Bore SA105 CS WN Flg					14
13	1	Style W07 Rigid Coupling					14
6	2	150lb CS Flange Cap Screw Set					10 (7/8x2-1/4)
8	1	LD-2000 Butterfly Valve Gear Op					10
10	1	3000# FS Thread-0-Let			1 1/2"	1.500	2x14
3	3	3000# FS Thread-0-Let			1 1/16"	1.063	3/4x14
2	1	Std Wt SA-53B CS ERW Pipe PE	BEV	Grooved End	18'-9"	225.029	14

BOM-STEEL

Item No	Order	Description	Qty	Size	Steel L
S1		ASTM A36 CS Plate 1/2" Thick	1	6x4x1/2	0"
S2		ASTM A36 CS Plate 1/2" Thick	1	12x6x1/2	0"



1233 N. Price Rd.
St. Louis, MO 63132-2303
314-997-6600 phone
BIMCAD@murphy-stl.com

<input type="checkbox"/>	FLANGE WEIGHT/ORIENTATION						
<input type="checkbox"/>	FITTING ORIENTATION						
<input type="checkbox"/>	BOLTS/CPLG'S/TH'D TIGHT						
<input type="checkbox"/>	SPOOL IDENTIFICATION						
QA/QC ACCEPT		SPEC.	ASME	X-RAY	HYDRO TEST	PWHT	COMMENTS
		NA	NA	NA	NA	NA	MURPHY WPS#
0	REV	DATE	DESCRIPTION		DRN	CHK	APP

DRN	JMM	5/17/2021	WUSM RESEARCH BUILDING				
CHK			NRB CUP				
APP			LVLO2 SPOOLS				
JOB NO.	210140		SERVICE NAME	HWS			
REF.DWG.							
DRAWING NO./TRACKING NO.	210140-A-UPL2-3-2	QTY.	1	SHT/NO	1 of 1	REV	0