



| Murphy—PFFS—SPOOL—BOM | | | | | | | |
|-----------------------|-----|--|-------------|-------------|--------|---------|------|
| Mark | Qty | Description | End 1 | End 2 | Lft | LDec | Size |
| 2 | 1 | Style 177 EHP QuickVic Flexible Coupling | | | | | 6 |
| 1 | 1 | Sch 40 SA-53B CS ERW Pipe PE | Grooved End | Grooved End | 20'-0" | 240.000 | 6 |

MURPHY
SINCE 1907

CONSTRUCTORS • ENGINEERS
MECHANICAL • INDUSTRIAL

1233 N. Price Rd.
St. Louis, MO 63132-2303
314-997-6600 phone
BIMCAD@murphy-stl.com

| | | | | | | | |
|--------------|------|---------------------------|------------|------|-------------|--------------------------|-----|
| QA/QC ACCEPT | | FLANGE WEIGHT/ORIENTATION | | | | <input type="checkbox"/> | |
| | | FITTING ORIENTATION | | | | <input type="checkbox"/> | |
| | | BOLTS/CPLG'S/TH'D TIGHT | | | | <input type="checkbox"/> | |
| | | SPOOL IDENTIFICATION | | | | <input type="checkbox"/> | |
| SPEC. | ASME | X-RAY | HYDRO TEST | PWHT | COMMENTS | | |
| NA | NA | NA | NA | NA | MURPHY WPS# | | |
| 0 | | | | | | | |
| REV | DATE | DESCRIPTION | | | DRN | CHK | APP |

| | | | | | | |
|--------------------------|--------------------|--------------|------------------------|--------|--------|-----|
| DRN | JMM | 5/14/2021 | WUSM RESEARCH BUILDING | | | |
| CHK | | | NRB CUP | | | |
| APP | | | LVLO2 SPOOLS | | | |
| JOB NO. | 210140 | SERVICE NAME | | | | |
| REF.DWG. | | HWR HRC | | | | |
| DRAWING NO./TRACKING NO. | 210140-A-UPL2-4-05 | QTY. | 1 | SHT/NO | 1 of 1 | REV |
| | | | | | | 0 |