



Murphy-PFFS-SPOOL-BOM							
Mark	Qty	Description	End 1	End 2	Lft	LDec	Size
10	1	Std Wt SA234 WPB CS BW CONC RED					14x10
8	1	Style W07 Rigid Coupling					14
12	1	77C-140 Brz 2pc FP SS-Vntd-B&S Ball Valve Thd					3/4
14	1	No.647 TT Dielectric Transition Fitting					3/4
2	1	Std Wt SA234 WPB CS BW LR 90 Deg Ell					10
6	1	Std Wt SA234 WPB CS BW 45 Deg Ell					10
1	1	3000# FS Thread-O-Let			1 5/16"	1.313	1x10
13	1	3000# FS Thread-O-Let			1 1/16"	1.063	3/4x10
5	1	Sch 40 SA-53B CS ERW Pipe PE	BEV	BEV	1'-0 7/16"	12.441	10
11	1	Sch 40 SA-53B CS ERW Pipe PE	BEV	BEV	1'-2 3/8"	14.375	10
7	1	Std Wt SA-53B CS ERW Pipe PE	Grooved End	BEV	6"	6.000	14
4	1	Sch 40 SA-53B CS ERW Pipe PE	BEV	Grooved End	6"	6.000	10

MURPHY SINCE 1907 <small>CONSTRUCTORS • ENGINEERS MECHANICAL • INDUSTRIAL</small>							
1233 N. Price Rd. St. Louis, MO 63132-2303 314-997-6600 phone BIMCAD@murphy-stl.com							
		QA/QC ACCEPT _____		FLANGE WEIGHT/ORIENTATION <input type="checkbox"/>			
				FITTING ORIENTATION <input type="checkbox"/>			
				BOLTS/CPLG'S/TH'D TIGHT <input type="checkbox"/>			
				SPOOL IDENTIFICATION <input type="checkbox"/>			
		SPEC.	ASME	X-RAY	HYDRO TEST	PWHT	COMMENTS
		NA	NA	NA	NA	NA	MURPHY WPS#
		0					
		REV	DATE	DESCRIPTION			CHK APP
WUSM RESEARCH BUILDING NRB CUP LVL02 SPOOLS							
		SERVICE NAME		CH#5 CHWR		REV	
DRAWING NO./TRACKING NO.		QTY.		SHT/NO		REV	
210140-A-UPL2-20-06		1		1 OF 1		0	
DRN JMM	5/12/2021						
CHK							
APP							
JOB NO.	210140						
REF.DWG.							