



BIM 360//WUSM NRBWUSM\_RB\_SPOOLING MASTER.rvt  
10/27/2021 5:54:21 PM



1 AS-L06-030 - ISOMETRIC  
SCALE:

2 AS-L06-030  
SCALE: 1/2" = 1'-0"




A1	A3	B1	B3
A2	A4	B2	B4

JOB: WASH U NRB

TICKET: AS-L06-030

Drawn By: Author

DATE REQ: 10/27/21




1233 N. Price Rd.  
St. Louis, Mo 63132-2303  
314-997-6600 phone


BIM 360://WUSM NRBWUSM\_RB\_HPF.rvt  
10/13/2021 12:55:45 PM

Mark	Qty	Size	Description	Length	Strut Width	Rob 1	Rob 2	Insulation
01	2	6"	B-Line B2000 ZN-Gal 10 Pipe Clamp					
02	2	5"	B-Line B2000 ZN-Gal 10 Pipe Clamp					
03	4	4"	B-Line B2000 ZN-Gal 10 Pipe Clamp					
04	2	28"	B-Line 1-5/8 GRN 12GA Bk/Bk 2in Slotted Unistrut		2' - 8"	4' - 0 5/8"	4' - 0 5/8"	


01	4	6 5/8"	B-LINE #2020
02	4	5 1/8"	B-LINE #2062
03	4	4 1/8"	B-LINE #2054



1 ISOMETRIC  
SCALE:



2 TOP VIEW  
SCALE: 1/2" = 1'-0"



3 FRONT ELEVATION  
SCALE: 1/2" = 1'-0"


A1	A3	B1	B3
A2	A4	B2	B4

JOB: WASH U NRB

TICKET: HPHGR-L06-030

Drawn By: Author


DATE: 10/10/21 DATE REQ:




1233 N. Price Rd.  
St. Louis, Mo 63132-2303  
314-997-6600 phone

BIM 360://WUSM NRBWUSM\_RB\_HPF.rvt  
21-10-2021 09:25:50

Mark	Qty	Size	Description	Length	Strut Width	Rob 1	Rob 2	Insulation
01	1	2"	Cerro Type K Hard Copper Pipe	7'-1 15/16"				1"
02	1	2"	Cerro Type K Hard Copper Pipe	5'-10 9/16"				1"
03	1	2"	Cerro Type K Hard Copper Pipe	0'-10 9/16"				1"
04	1	2"	Nibco Wrot 607 90 Deg Ell CxC					1"
05	2	2"	Nibco Wrot 606 45 Deg Ell CxC					1"




1 ISOMETRIC



2 LEFT ELEVATION  
SCALE: 1/2" = 1'-0"

A1	A3	B1	B3
A2	A4	B2	B4


JOB: WASH U NRB  
TICKET: CHS-L06-030  
Drawn By: Author  
DATE: 10/21/21  
DATE REQ:




1233 N. Price Rd.  
St. Louis, Mo 63132-2303  
314-997-6600 phone

BIM 360://WUSM NRBWUSM\_RB\_HPF.rvt  
21-10-2021 07:26:12

Mark	Qty	Size	Description	Length	Strut Width	Rob 1	Rob 2	Insulation
01	1	2"	Cerro Type K Hard Copper Pipe	0'-9 15/16"				1"
02	1	2"	Cerro Type K Hard Copper Pipe	7'-1 15/16"				1"
03	1	2"	Cerro Type K Hard Copper Pipe	5'-3 7/16"				1"
04	1	2"	Nibco Wrot 607 90 Deg Ell CxC					1"
05	2	2"	Nibco Wrot 606 45 Deg Ell CxC					1"




1 ISOMETRIC



2 LEFT ELEVATION  
SCALE: 1/2" = 1'-0"

A1	A3	B1	B3
A2	A4	B2	B4


JOB: WASH U NRB  
TICKET: CHR-L06-030  
Drawn By: Author  
DATE: 10/21/21  
DATE REQ:




1233 N. Price Rd.  
St. Louis, Mo 63132-2303  
314-997-6600 phone

BIM 360://WUSM NRBWUSM\_RB\_HPF.rvt  
10/19/2021 12:23:29 PM

Mark	Qty	Size	Description	Length	Strut Width	Rob 1	Rob 2	Insulation
01	1	2"	Cerro Type K Hard Copper Pipe	7'-0 11/16"				1 1/2"
02	1	2"	Cerro Type K Hard Copper Pipe	4'-8 3/8"				1 1/2"
03	1	2"	Cerro Type K Hard Copper Pipe	0'-10 3/8"				1 1/2"
04	1	2"	Nibco Wrot 607 90 Deg Ell CxC					1 1/2"
05	2	2"	Nibco Wrot 606 45 Deg Ell CxC					1 1/2"




1 ISOMETRIC



2 RIGHT ELEVATION  
SCALE: 3/4" = 1'-0"

A1	A3	B1	B3
A2	A4	B2	B4


JOB: WASH U NRB  
TICKET: HWS-L06-030  
Drawn By: Author  
DATE: 10/10/21  
DATE REQ:




1233 N. Price Rd.  
St. Louis, Mo 63132-2303  
314-997-6600 phone

BIM 360://WUSM NRBWUSM\_RB\_HPF.rvt  
21-10-2021 11:02:46

Mark	Qty	Size	Description	Length	Strut Width	Rob 1	Rob 2	Insulation
01	1	3"	Chicago Area Sch 40 SA-53B CS ERW Pipe PE	0'-9 5/8"				1 1/2"
02	1	3"	Chicago Area Sch 40 SA-53B CS ERW Pipe PE	6'-9 3/4"				1 1/2"
03	1	3"	Chicago Area Sch 40 SA-53B CS ERW Pipe PE	3'-7 9/16"				1 1/2"
04	1	3"	Weldbend Std Wt SA234 WPB CS BW LR 90 Deg Ell					1 1/2"
05	2	3"	Weldbend Std Wt SA234 WPB CS BW 45 Deg Ell					1 1/2"




1 ISOMETRIC  
SCALE:



2 RIGHT ELEVATION  
SCALE: 1/2" = 1'-0"

A1	A3	B1	B3
A2	A4	B2	B4

JOB:	WASH U NRB
TICKET:	HWR-L06-030
Drawn By: Author	
DATE: 10/21/21	DATE REQ:



1233 N. Price Rd.  
St. Louis, Mo 63132-2303  
314-997-6600 phone