



CT-1 INLET

# Murphy-PFFS-SPOOL-BOM

Mark	Qty	Description	End 1	End 2	Lft	LDec	Size
2	1	Std Wt SA234 WPB CS BW CONC RED					14x12
5	1	150lb RF Sch 40 Bore SA105 CS WN Flg					12
13	3	150lb RF Sch 40 Bore SA105 CS WN Flg					14
8	3	Style W77 Rigid Coupling					14
3	1	150# CS Flange Bolt Set					12 (7/8x4-1/4)
4	1	150# FF Garlock Gasket 1/16 Thick					12
14	4	150lb CS Flange Cap Screw Set					14 (1x2-3/4)
17	1	LD-1000 Butterfly Valve					14
11	1	150 lb Brz 2pc FP Ball Valve Thd					2
9	2	Std Wt SA234 WPB CS BW LR 90 Deg Ell					14
10	1	3000# FS Thread-O-Let			1 1/2"	1.500	2x14
7	1	Std Wt SA-53B CS ERW Pipe PE	Grooved End	BEV	1'-10 1/16"	22.041	14
16	1	Std Wt SA-53B CS ERW Pipe PE	BEV	BEV	4"	3.993	14
1	1	Std Wt SA-53B CS ERW Pipe PE	BEV	Grooved End	6"	6.000	14
6	2	Std Wt SA-53B CS ERW Pipe PE	Grooved End	Grooved End	10"	10.000	14
12	1	Std SA-53B CS Smls Pipe NIP x 3	MPT	MPT	3"	3.000	2
15	1	Valve-Butterfly-2_Way-Belimo-F6_SY4_SY5_SY6-Non_Spring_14.00 in_F6350HD+SY5-120MFT					14



QA/QC ACCEPT					FLANGE WEIGHT/ORIENTATION		<input type="checkbox"/>
					FITTING ORIENTATION		<input type="checkbox"/>
					BOLTS/CPLG'S/TH'D TIGHT		<input type="checkbox"/>
					SPOOL IDENTIFICATION		<input type="checkbox"/>
SPEC.	ASME	X-RAY	HYDRO	TEST	PWHT	COMMENTS	
NA	NA	NA	NA	NA	NA	MURPHY WPS#	
0							
REV	DATE	DESCRIPTION				DRN	CHK APP

DRN JMM	6/14/2021	WUSM RESEARCH BUILDING		
CHK		NRB		
APP		LVLO3 CT SPOOLS		
JOB NO.	210140	SERVICE NAME		
REF.DWG.		TWR		
DRAWING NO./TRACKING NO. 210140-A-UPL3-2D		QTY. 1	SHT/NO 1 of 1	REV 0