



BIM 360//WUSM NRBWUSM RB HPF.rvt
7/23/2021 3:03:31 PM



1 HP-L00-099
SCALE:



2 HP-L00-099 TOP VIEW
SCALE:

A1	A3	B1	B3
A2	A4	B2	B4

JOB: WASH U NRB

TICKET:

Drawn By: Author


DATE: 06/17/21 DATE REQ:



1233 N. Price Rd.
St. Louis, Mo 63132-2303
314-997-6600 phone

BIM 360://WUSM NRBWUSM_RB_HPF.rvt
7/28/2021 10:17:19 AM

Mark	Qty	Size	Description	Strut Width	Rod 1	Rod 2
01	6	4"	B-Line B2000 ZN Sch 40 Pipe Clamp			
02	6	3.5"	B-Line B2000 ZN Sch 40 Pipe Clamp			
03	3	2.5"	B-Line B2000 ZN Sch 40 Pipe Clamp			
04	1	44"	B-Line 1-5/8 GRN 12GA Bk/Bk 2in Slotted Unistrut	4' - 0"	1' - 9"	1' - 9"
05	1	44"	B-Line 1-5/8 GRN 12GA Bk/Bk 2in Slotted Unistrut	4' - 0"	1' - 11"	2' - 6"
06	1	44"	B-Line 1-5/8 GRN 12GA Bk/Bk 2in Slotted Unistrut	4' - 0"	1' - 10"	2' - 6"
07	6	N/A	B218 Roller	12"		
08	2	N/A	B-Line 1-5/8 BK/BK 12GA Strut	9'-10 3/8"		
09	3	N/A	7_8x1-5_8 Slotted Strut	8"		




- GENERAL NOTES**
- NOTE THAT FIG 165 ANVIL PIPE SADDLES ARE TO BE USED WITH THE B218 ROLLERS.
 - "A" DIMENSION IS SHOWN AS STRUT LENGTH ON BOM
 - NOTE THAT THE "SIZE" COLUMN IS INCORRECT FOR ALL UNISTRUT PIECES AND SHOULD BE IGNORED.
 - NOTE THAT THE "STRUT WIDTH" COLUMN IS THE END TO END DIMENSION OF THE STRUT PIECE.

FAB NOTES 2

SCALE: 1/4" = 1'-0"


B218
Pipe Rollers - 1/2" (15) to 8" (200) Pipe



1

ISOMETRIC

SCALE:



2


TOP VIEW

SCALE: 3/4" = 1'-0"

3

RIGHT ELEVATION

SCALE: 3/4" = 1'-0"




A1	A3	B1	B3
A2	A4	B2	B4

JOB: WASH U NRB

TICKET: HPHGR-L00-099

Drawn By: Author


DATE REQ: 06/15/21




1233 N. Price Rd.
St. Louis, Mo 63132-2303
314-997-6600 phone

BIM 360://WUSM NRBWUSM_RB_HPF.rvt
7/26/2021 12:24:31 PM

Mark	Qty	Size	Description	Length	End Prep	Insulation
01	1	1 1/2"	Cerro Type L Hard Copper Pipe	14'-8 1/8"		1"
02	1	1 1/2"	Nibco Wrot 607 90 Deg Ell CxC			1"




1 ISOMETRIC
SCALE:



2 TOP VIEW
SCALE: 3/4" = 1'-0"

A1	A3	B1	B3
A2	A4	B2	B4

JOB:	WASH U NRB
TICKET:	CHR-L00-099
Drawn By: Author	
DATE: 06/11/21	DATE REQ:



1233 N. Price Rd.
St. Louis, Mo 63132-2303
314-997-6600 phone

BIM 360://WUSM NRBWUSM_RB_HPF.rvt
7/26/2021 12:24:36 PM

Mark	Qty	Size	Description	Length	End Prep	Insulation
01	1	1 1/2"	Cerro Type L Hard Copper Pipe	15'-7 15/16"		1"
02	1	1 1/2"	Nibco Wrot 607 90 Deg Ell CxC			1"

CONNECT TO CHS-L00-053

01

SHIP
LOOSE

CONNECT TO CHS-L00-100

02

ISOMETRIC

15' - 9"

TOP VIEW
3/4" = 1'-0"


A1	A3	B1	B3
A2	A4	B2	B4

JOB: WASH U NRB

TICKET: CHS-L00-099

Drawn By: Author


DATE REQ: 07/23/21



1233 N. Price Rd.
St. Louis, Mo 63132-2303
314-997-6600 phone

BIM 360://WUSM NRBWUSM_RB_HPF.rvt
7/26/2021 12:24:42 PM

Mark	Qty	Size	Description	Length	End Prep	Insulation
01	1	6"	Chicago Area XH SA-53B CS SMLS Pipe	4'-8 1/8"	BVL X BVL	4 1/2"
02	1	6"	Chicago Area XH SA-53B CS SMLS Pipe	14'-6 3/16"	BVL X BVL	4 1/2"
03	1	6"	Weldbend XH SA234 WPB CS BW LR 90 Deg Ell			4 1/2"
04	2	6"	Weldbend XH SA234 WPB CS BW 45 Deg Ell			4 1/2"



1 ISOMETRIC

SCALE:




2 FRONT ELEVATION

SCALE: 3/4" = 1'-0"

A1	A3	B1	B3
A2	A4	B2	B4


JOB:	WASH U NRB
TICKET:	MPC-L00-099
Drawn By: Author	
DATE: 06/11/21	DATE REQ:




1233 N. Price Rd.
St. Louis, Mo 63132-2303
314-997-6600 phone

BIM 360://WUSM NRBWUSM_RB_HPF.rvt
7/26/2021 12:24:47 PM

Mark	Qty	Size	Description	Length	End Prep	Insulation
01	1	6"	Chicago Area Sch 40 SA-53B CS Smls Pipe PE	3'-2 1/2"	BVL X BVL	4 1/2"
02	1	6"	Chicago Area Sch 40 SA-53B CS Smls Pipe PE	12'-10 3/16"	BVL X BVL	4 1/2"
03	1	6"	Weldbend Std Wt SA234 WPB CS BW LR 90 Deg Ell			4 1/2"
04	2	6"	Weldbend Std Wt SA234 WPB CS BW 45 Deg Ell			4 1/2"




1 ISOMETRIC
SCALE:



5 FRONT ELEVATION
SCALE: 3/4" = 1'-0"

A1	A3	B1	B3
A2	A4	B2	B4


JOB:	WASH U NRB
TICKET:	MPS-L00-099
Drawn By: Author	
DATE: 06/11/21	DATE REQ:




1233 N. Price Rd.
St. Louis, Mo 63132-2303
314-997-6600 phone

BIM 360://WUSM NRBWUSM_RB_HPF.rvt
7/26/2021 12:24:53 PM

Mark	Qty	Size	Description	Length	End Prep	Insulation
01	1	4"	Chicago Area Sch 40 SA-53B CS Smls Pipe PE	17'-0 1/2"	BVL X BVL	
02	1	2 1/2"	Chicago Area Sch 40 SA-53B CS Smls Pipe PE	16'-2 9/16"	BVL X BVL	
03	1	4"	Chicago Area Sch 40 SA-53B CS Smls Pipe PE	15'-5 3/16"	BVL X BVL	
04	1	4"	Weldbend Std Wt SA234 WPB CS BW LR 90 Deg Ell			
05	1	2 1/2"	Weldbend Std Wt SA234 WPB CS BW LR 90 Deg Ell			
06	1	4"	Weldbend Std Wt SA234 WPB CS BW 45 Deg Ell			




ISOMETRIC



TOP VIEW
3/4" = 1'-0"

A1	A3	B1	B3
A2	A4	B2	B4

JOB:	WASH U NRB
TICKET:	V-L00-099
Drawn By: Author	
DATE: 07/23/21	DATE REQ:



1233 N. Price Rd.
St. Louis, Mo 63132-2303
314-997-6600 phone