



Murphy—PFFS—SPOOL—BOM

Mark	Qty	Description	End 1	End 2	Lft	LDec	Size
5	1	Style 107 EHP Pnt QuickVic Rigid Coupling					4
2	1	Std Wt SA234 WPB CS BW LR 90 Deg El					4
1	1	Sch 40 SA-53B CS ERW Pipe PE	BEV	Grooved End	6 3/4"	6.722	4
4	1	Sch 40 SA-53B CS ERW Pipe PE	BEV	Grooved End	4'-4 5/8"	52.634	4

MURPHY
SINCE 1907

CONSTRUCTORS • ENGINEERS MECHANICAL • INDUSTRIAL

1233 N. Price Rd.
St. Louis, MO 63132-2303
314-997-6600 phone
BIMCAD@murphy-stl.com

<input type="checkbox"/> FLANGE WEIGHT/ORIENTATION	
<input type="checkbox"/> FITTING ORIENTATION	
<input type="checkbox"/> BOLTS/CPLG'S/TH'D TIGHT	
<input type="checkbox"/> SPOOL IDENTIFICATION	

QA/QC ACCEPT		HYDRO TEST		PWHT		COMMENTS	
SPEC.	ASME	X-RAY	NA	NA	NA	MURPHY	WPS#
NA	NA	NA	NA	NA	NA		
0		DESCRIPTION		DRN	CHK	APP	
REV	DATE						

DRN JMM	5/14/2021	WUSM RESEARCH BUILDING			
CHK		NRB CUP			
APP		LVLO2 SPOOLS			
JOB NO.	210140	SERVICE NAME			
REF.DWG.		CHWR HRC			
DRAWING NO./TRACKING NO.	QTY.	SHT/NO	REV		
210140-A-UPL2-26-10	1	1 of 1	0		