



BIM 360//WUSM NRBWUSM\_RB\_SPOOLING MASTER.rvt  
1/5/2022 12:27:13 PM

CUT AND PACKAGE ONLY  
DO NOT ASSEMBLE



1 AS-L06-080 - ISOMETRIC  
AS-L06-080 SCALE:



2 AS-L06-080  
AS-L06-080 SCALE: 1/2" = 1'-0"

A1	A3	B1	B3
A2	A4	B2	B4




1233 N. Price Rd.  
St. Louis, Mo 63132-2303  
314-997-6600 phone

JOB:	WASH U NRB
TICKET:	AS-L06-080
Drawn By: Author	
DATE: 11/01/21	DATE REQ:


BIM 360://WUSM NRBWUSM\_RB\_PUF.rvt  
1/5/2022 9:35:35 AM

Mark	Qty	Size	Description	Length	Insulation	ROD 1	ROD 2	Strut Width
01	1	3/4"	Cerro Type L Hard Copper - CFOS	6'-2 1/4"				
02	1	3/4"	Cerro Type L Hard Copper - CFOS	4'-8 7/8"				
03	1	3/4"	Cerro Type L Hard Copper - CFOS	4'-6 3/8"				
04	1	3/4"	Cerro Type L Hard Copper - CFOS	4'-6 1/8"				
05	1	3/4"	Cerro Type L Hard Copper - CFOS	4'-3 3/8"				
06	1	3/4"	Cerro Type L Hard Copper - CFOS	4'-0 3/4"				
07	1	3/4"	Cerro Type L Hard Copper - CFOS	2'-1 3/4"				
08	1	3/4"	Cerro Type L Hard Copper - CFOS	1'-11 7/8"				
09	1	3/4"	Cerro Type L Hard Copper - CFOS	1'-9 3/4"				
10	1	3/4"	Cerro Type L Hard Copper - CFOS	1'-5 1/2"				
11	1	3/4"	Cerro Type L Hard Copper - CFOS	1'-5 1/4"				
12	1	3/4"	Cerro Type L Hard Copper - CFOS	1'-5 1/8"				
13	1	3/4"	Cerro Type L Hard Copper - CFOS	1'-4 1/2"				
14	1	3/4"	Cerro Type L Hard Copper - CFOS	1'-4 1/8"				
15	8	3/4"	Nibco 607-CB CFOS Wrot 90 Elbow					
16	4	3/4"	Nibco 600-DS-CB CFOS Wrot Copper Coupling Staked Stop					
17	4	3/4"	Elkhart 100 Wrot Coupling with Stop					
18	2	3/4"	Beacon Medaes SSB-820-10 Brz 3pc Dual FP Shut-Off wLk Lvr Valve					
19	7	0.75"	B-Line BVT Series Vibra-Clamp Strut-Mnt Tube - ZN				0"	
20	2	34 1/4"	B-Line 1-5/8 GRN 12GA 2in Slotted Unistrut					3' - 4"



Elevation Top

SCALE: 3/4" = 1'-0"



ISOMETRIC


A1	A3	B1	B3
A2	A4	B2	B4

JOB: WASH U NRB

TICKET: PU-L06-080

Drawn By: Author

DATE REQ: 01/05/22



1233 N. Price Rd.  
St. Louis, Mo 63132-2303  
314-997-6600 phone