



BIM 360://WUSM NRBWUSM_RB_HPF.rvt
7/26/2021 12:18:23 PM




1 HP-L00-101
SCALE:



2 HP-L00-101 TOP VIEW
SCALE:

A1	A3	B1	B3
A2	A4	B2	B4


JOB:	WASH U NRB
TICKET:	
Drawn By: Author	
DATE: 06/17/21	DATE REQ:



1233 N. Price Rd.
St. Louis, Mo 63132-2303
314-997-6600 phone

BIM 360//WUSM NRBWUSM RB HPF.rvt
7/28/2021 10:18:05 AM

Mark	Qty	Size	Description	Strut Width	Rod 1	Rod 2
01	6	4"	B-Line B2000 ZN Sch 40 Pipe Clamp			
02	6	3.5"	B-Line B2000 ZN Sch 40 Pipe Clamp			
03	3	2.5"	B-Line B2000 ZN Sch 40 Pipe Clamp			
04	3	68"	B-Line 1-5/8 GRN 12GA Bk/Bk 2in Slotted Unistrut	6' - 0"	1' - 8"	2' - 11"
05	6	N/A	B218 Roller	12"		
06	5	N/A	B-Line 1-5/8 BK/BK 12GA Strut	10'-2 1/8"		
07	3	N/A	7_8x1-5_8 Slotted Strut	6"		




- GENERAL NOTES**
- NOTE THAT FIG 165 ANVIL PIPE SADDLES ARE TO BE USED WITH THE B218 ROLLERS.
 - "A" DIMENSION IS SHOWN AS STRUT LENGTH ON BOM
 - NOTE THAT THE "SIZE" COLUMN IS INCORRECT FOR ALL UNISTRUT PIECES AND SHOULD BE IGNORED.
 - NOTE THAT THE "STRUT WIDTH" COLUMN IS THE END TO END DIMENSION OF THE STRUT PIECE.

FAB NOTES 2


SCALE: 1/4" = 1'-0"

B218
Pipe Rollers - 1/2" (15) to 8" (200) Pipe



1 ISOMETRIC


SCALE:



2 TOP VIEW

SCALE: 3/4" = 1'-0"

A1	A3	B1	B3
A2	A4	B2	B4



3 FRONT ELEVATION


SCALE: 3/4" = 1'-0"

JOB: WASH U NRB

TICKET: HPHGR-L00-101

Drawn By: Author



DATE REQ: 06/15/21



1233 N. Price Rd.
St. Louis, Mo 63132-2303
314-997-6600 phone

BIM 360://WUSM NRBWUSM_RB_HPF.rvt
7/26/2021 12:20:23 PM


Mark	Qty	Size	Description	Length	End Prep	Insulation
01	1	1 1/2"	Cerro Type L Hard Copper Pipe	18'-8 5/16"		1"
02	1	1 1/2"	Nibco Wrot 607 90 Deg Ell CxC			1"



LEFT ELEVATION
3/4" = 1'-0"

A1	A3	B1	B3
A2	A4	B2	B4


JOB:	WASH U NRB
TICKET:	CHS-L00-101
Drawn By: Author	
DATE: 07/26/21	DATE REQ:



1233 N. Price Rd.
St. Louis, Mo 63132-2303
314-997-6600 phone


BIM 360://WUSM NRBWUSM_RB_HPF.rvt
7/26/2021 12:10:29 PM

Mark	Qty	Size	Description	Length	End Prep	Insulation
01	1	1 1/2"	Cerro Type L Hard Copper Pipe	19'-2 15/16"		1"
02	1	1 1/2"	Nibco Wrot 607 90 Deg Ell CxC			1"



1 ISOMETRIC

SCALE:




2 RIGHT ELEVATION

SCALE: 3/4" = 1'-0"

A1	A3	B1	B3
A2	A4	B2	B4


JOB:	WASH U NRB
TICKET:	CHR-L00-101
Drawn By: Author	
DATE: 06/11/21	DATE REQ:




1233 N. Price Rd.
St. Louis, Mo 63132-2303
314-997-6600 phone

BIM 360://WUSM NRB\\WUSM_RB_HPF.rvt
7/26/2021 12:10:48 PM

Mark	Qty	Size	Description	Length	End Prep	Insulation
01	1	6"	Chicago Area XH SA-53B CS SMLS Pipe	16'-5 5/16"	BVL X BVL	4 1/2"
02	1	6"	Weldbend XH SA234 WPB CS BW Cap			4 1/2"




1 ISOMETRIC
SCALE:



2 RIGHT ELEVATION
SCALE: 3/4" = 1'-0"

A1	A3	B1	B3
A2	A4	B2	B4


JOB:	WASH U NRB
TICKET:	MPC-L00-101
Drawn By: Author	
DATE: 06/11/21	DATE REQ:



1233 N. Price Rd.
St. Louis, Mo 63132-2303
314-997-6600 phone

BIM 360://WUSM NRBWUSM RB HPF.rvt
7/26/2021 12:10:49 PM

Mark	Qty	Size	Description	Length	End Prep	Insulation
01	1	2 1/2"	Chicago Area Sch 40 SA-53B CS Smls Pipe PE	17'-8"	BVL X BVL	
02	1	4"	Chicago Area Sch 40 SA-53B CS Smls Pipe PE	16'-8 9/16"	BVL X BVL	
03	1	4"	Chicago Area Sch 40 SA-53B CS Smls Pipe PE	16'-2 13/16"	BVL X BVL	
04	1	2 1/2"	Chicago Area Sch 40 SA-53B CS Smls Pipe PE	0'-10 1/8"	BVL X BVL	
05	4	4"	Weldbend Std Wt SA234 WPB CS BW LR 90 Deg Ell			
06	1	2 1/2"	Weldbend Std Wt SA234 WPB CS BW LR 90 Deg Ell			
07	1	2 1/2"	Weldbend Std Wt SA234 WPB CS BW 45 Deg Ell			



ISOMETRIC



LEFT ELEVATION
3/4" = 1'-0"

A1	A3	B1	B3
A2	A4	B2	B4


JOB: WASH U NRB

TICKET: V-L00-101

Drawn By: Author

DATE: 07/26/21

DATE REQ:



1233 N. Price Rd.
St. Louis, Mo 63132-2303
314-997-6600 phone