


Mark	Qty	Description	Size	Length	Insulation	
01	1	Chicago Area Sch 40 SA-53B CS ERW Pipe PE	3"	0'-9 7/16"	1"	
02	1	Chicago Area Sch 40 SA-53B CS ERW Pipe PE	3"	0'-6 13/16"	1"	
03	2	Chicago Area Sch 40 SA-53B CS ERW Pipe PE	3"	0'-5 9/16"	1"	
04	1	Chicago Area Sch 40 SA-53B CS ERW Pipe PE	3"	0'-4"	1"	
05	1	Chicago Area Sch 40 SA-53B CS ERW Pipe PE	3"	2'-9 13/16"	1"	
06	2	Chicago Area Sch 40 SA-53B CS ERW Pipe PE	3"	1'-3 1/2"	1"	
07	1	Chicago Area Sch 40 SA-53B CS ERW Pipe PE	3"	1'-1 1/16"	1"	
08	1	Chicago Area Sch 40 SA-53B CS ERW Pipe PE	3"	1'-0 13/16"	1"	
09	1	Anvil Std SA-53B CS Smls Pipe NIP x Close	3/4"	0'-1 3/8"	1"	
10	2	VIC-300 MASTERSEAL BUTTERFLY VALVE BARE	3"		0"	
11	2	Weldbend Std Wt SA234 WPB CS BW TEE	3"		1"	NRB
12	1	Weldbend Std Wt SA234 WPB CS BW SR 90 Deg Ell	3"		1"	=
13	1	Weldbend Std Wt SA234 WPB CS BW Cap	3"		1"	$\rceil \supset $
14	2	Weldbend Std Wt SA234 WPB CS BW 45 Deg Ell	3"		1"	│ 픘 │
15	6	Victaulic Style 177 EHP QuickVic Flexible Coupling	3"		1"	WASH
16	1	Apollo 77C-140 Brz 2pc FP SS-Vntd-B&S Ball Valve Thd	3/4"		1"	$\rceil \geqslant $
17	5	Anvil 3000# FS Thread-O-Let	3"x3/4"		1"	JOB:



Elevation Back		
1" = 1'-0"		

	>
>	

тіскет: AS-L02-255

Drawn By: Author DATE: 10/21/21

1233 N. Price Rd.
St. Louis, Mo 63132-2303
314-997-6600 phone

A1	A3	B1	В3
A2	A4	B2	В4

Elevation Top 1" = 1'-0"