



BIM 360/WUSM NRBWUSM\_RB\_SPOOLING MASTER.rvt  
12/16/2021 1:30:37 PM




1 **AS-L07-046 - ISOMETRIC**  
AS-L07-046 SCALE:



2 **AS-L07-046**  
AS-L07-046 SCALE: 1/2" = 1'-0"


A1	A3	B1	B3
A2	A4	B2	B4

JOB: **WASH U NRB**  
TICKET: **AS-L07-046**  
Drawn By: Author  
DATE: 11/19/21  
DATE REQ:




1233 N. Price Rd.  
St. Louis, Mo 63132-2303  
314-997-6600 phone

BIM 360://WUSM NRBWUSM\_RB\_HPF.rvt  
12/16/2021 9:51:01 AM



Mark	Qty	Size	Description	Length	Strut Width	Rob 1	Rob 2	Insulation
01	2	3/4"	Victaulic No.647 TT Dielectric Transition Fitting	0'-3"				1"
02	1	3"	Chicago Area Sch 40 SA-53B CS ERW Pipe PE	19'-11 7/8"				1 1/2"
03	1	2 1/2"	Cerro Type K Hard Copper Pipe	17'-10"				1 1/2"
04	1	3"	Chicago Area Sch 40 SA-53B CS ERW Pipe PE	1'-6 11/16"				1 1/2"
05	2	3/4"	Cerro Type K Hard Copper Pipe	0'-1"				1"
06	1	3"x2 1/2"	Weldbend Std Wt SA234 WPB CS BW CONC RED					1 1/2"
07	1	2 1/2"	Weldbend 150lb RF Sch 40 Bore SA105 CS WN Flg					1 1/2"
08	2	3/4"	Nibco Wrot 607 90 Deg Ell CxC					1"
09	2	3/4"	Nibco Wrot 603 Adapter CxF					1"
10	1	2 1/2"	Nibco Wrot 600 Dimpled Stop Coupling CxC					1 1/2"
11	1	2 1/2"	Nibco 150lb 672 2pc LF Compainion Flange					1 1/2"
12	1	2 1/2"	Generic 150# RF Garlock Gasket 1/16 Thick					1 1/2"
13	1	2 1/2"	Generic 150# CS Flange Bolt Set					
14	2	3"x3/4"	Anvil 3000# FS Thread-O-Let					1"
15	8	6"	B-Line B2000 ZN Sch 40 Pipe Clamp		0"		0"	
16	1	26"	B-Line 1-5/8 GLV 12GA Bk/Bk 2in Slotted Unistrut		2' - 6"	2' - 8 5/8"	4' - 0 5/8"	
17	1	22"	B-Line 1-5/8 GLV 12GA Bk/Bk 2in Slotted Unistrut		2' - 2"	2' - 8 5/8"	2' - 8 5/8"	
18	2	22"	B-Line 1-5/8 GLV 12GA Bk/Bk 2in Slotted Unistrut		2' - 2"	2' - 8 5/8"	4' - 0 5/8"	

1 ISOMETRIC  
SCALE:




2 TOP VIEW  
SCALE: 1 : 26



3 FRONT ELEVATION  
SCALE: 1 : 26

A1	A3	B1	B3
A2	A4	B2	B4

JOB: 210140 - WASH U NRB  
TICKET: HP-L07-046  
Drawn By: Author  
DATE: 11/18/21  
DATE REQ:



1233 N. Price Rd.  
St. Louis, Mo 63132-2303  
314-997-6600 phone