



## Murphy-PFFS-SPOOL-BOM

Mark	Qty	Description	End 1	End 2	Lft	LDec	Size
5	1	Std Wt SA234 WPB CS BW TEE					14
7	1	Sch 40 SA-53B CS ERW Pipe Saddle			4"	4.000	14x6
1	2	150lb RF Sch 40 Bore SA105 CS WN Flg					14
8	2	Style 107N QuickVic EHP Pnt Rigid Cpl					6
11	1	Style W07 Rigid Coupling					14
9	1	No. 60 Cap					6
10	1	761 MSTRSL Lever Hand MS O Seat					6
4	1	Std Wt SA234 WPB CS BW LR 90 Deg El					14
3	1	Std Wt SA-53B CS ERW Pipe PE	BEV	BEV	6'-7 5/8"	79.634	14
6	1	Std Wt SA-53B CS ERW Pipe PE	BEV	Grooved End	1'-2 15/16"	14.908	14

**MURPHY**  
SINCE 1907

CONSTRUCTORS • ENGINEERS  
MECHANICAL • INDUSTRIAL

1233 N. Price Rd.  
St. Louis, MO 63132-2303  
314-997-6600 phone  
BIMCAD@murphy-stl.com

<input type="checkbox"/>	FLANGE WEIGHT/ORIENTATION
<input type="checkbox"/>	FITTING ORIENTATION
<input type="checkbox"/>	BOLTS/CPLG'S/TH'D TIGHT
<input type="checkbox"/>	SPOOL IDENTIFICATION

QA/QC ACCEPT	ASME	X-RAY	HYDRO TEST	PWHT	COMMENTS
	NA	NA	NA	NA	MURPHY WPS#

1	6/28/21	CHANGED	VALVE TYPE	JMM
REV	DATE	DESCRIPTION	DRN	CHK APP

DRN JMM	5/18/2021	WUSM RESEARCH BUILDING	
CHK		NRB CUP	
APP		LVLO2 SPOOLS	
JOB NO.	210140	SERVICE NAME	
REF.DWG.		HWR	
DRAWING NO./TRACKING NO.	QTY.	SHT/NO	REV
210140-A-UPL2-13-5REV1	1	1 of 1	1