


BIM 360://WUSM NRBWUSM_RB_HP.rvt
10/5/2021 9:24:11 AM

1 AHU-22
SCALE:




A1	A3	B1	B3
A2	A4	B2	B4

JOB: WASH U NRB

TICKET:


Drawn By: Author

DATE: 10/05/21 DATE REQ:




1233 N. Price Rd.
St. Louis, Mo 63132-2303
314-997-6600 phone

BIM 360://WUSM NRBWUSM_RB_HPF.rvt
10/6/2021 10:45:30 AM



RIGHT ELEVATION
1" = 1'-0"


Mark	Qty	Description	Size	Length	Insulation
01	1	Chicago Area Sch 40 SA-53B CS ERW Pipe PE	3"	12'-4"	1"
02	1	Anvil Std SA-53B CS Smls Pipe NIP x Close	3/4"	0'-1 3/8"	1"
03	1	Weldbend Std Wt SA234 WPB CS BW Cap	3"		1"
04	2	Southern California Area Sch 40 SA-53B CS ERW Pipe Saddle	3"x2 1/2"		1"
05	1	Apollo 77C-140 Brz 2pc FP SS-Vntd-B&S Ball Valve Thd	3/4"		1"
06	3	Anvil 3000# FS Thread-O-Let	3"x3/4"		1"



ISOMETRIC


A1	A3	B1	B3
A2	A4	B2	B4

JOB:	WASH U NRB
TICKET:	CWR-L02-203
Drawn By: Author	
DATE: 10/04/21	DATE REQ:




1233 N. Price Rd.
St. Louis, Mo 63132-2303
314-997-6600 phone

BIM 360://WUSM NRBWUSM_RB_HPF.rvt
10/6/2021 10:46:29 AM



RIGHT ELEVATION
1" = 1'-0"


Mark	Qty	Description	Size	Length	Insulation
01	1	Chicago Area Sch 40 SA-53B CS ERW Pipe PE	3"	9'-8 3/8"	1"
02	1	Anvil Std SA-53B CS Smls Pipe NIP x Close	3/4"	0'-1 3/8"	1"
03	1	Weldbend Std Wt SA234 WPB CS BW Cap	3"		1"
04	2	Southern California Area Sch 40 SA-53B CS ERW Pipe Saddle	3"x2 1/2"		1"
05	1	Apollo 77C-140 Brz 2pc FP SS-Vntd-B&S Ball Valve Thd	3/4"		1"
06	3	Anvil 3000# FS Thread-O-Let	3"x3/4"		1"



ISOMETRIC

A1	A3	B1	B3
A2	A4	B2	B4

JOB: WASH U NRB
TICKET: CWS-L02-203
Drawn By: Author
DATE: 10/04/21
DATE REQ:



1233 N. Price Rd.
St. Louis, Mo 63132-2303
314-997-6600 phone