



BIM 360//WUSM NRBWUSM_RB_SPOOLING MASTER.rvt
17-11-2021 14:43:35



FABRICATE AND
PACKAGE ONLY. DO
NOT ASSEMBLE.


1 AS-L07-005 - ISOMETRIC
AS-L07-005 SCALE:



A1	A3	B1	B3
A2	A4	B2	B4

2 AS-L07-005
AS-L07-005 SCALE: 1/2" = 1'-0"

JOB: WASH U NRB
TICKET: AS-L07-005
Drawn By: Author
DATE: 11/17/21 DATE REQ:



1233 N. Price Rd.
St. Louis, Mo 63132-2303
314-997-6600 phone

BIM 360://WUSM NRBWUSM_RB_HPF.rvt
2/1/2022 11:42:34 AM


Mark	Qty	Size	Description	Length	Insulation	ROD 1	ROD 2	Strut Width
01	1	2 1/2"	Cerro Type K Hard Copper Pipe	3'-0 3/4"	1 1/2"			
02	1	3"	Chicago Area Sch 40 SA-53B CS ERW Pipe PE	19'-11 7/8"	1 1/2"			
03	1	2"	Cerro Type K Hard Copper Pipe	1'-8 3/4"	1 1/2"			
04	1	2 1/2"	Cerro Type K Hard Copper Pipe	14'-9 1/4"	1 1/2"			
05	1	3/4"	Victaulic No.647 TT Dielectric Transition Fitting		1"			
06	1	1 1/2"	Victaulic No.647 TT Dielectric Transition Fitting		1 1/2"			
07	1	2 1/2"x3/4"	Nibco Wrot 611R CxCxC Reducing Tee		1 1/2"			
08	1	2 1/2"x2"x1 1/2"	Nibco Wrot 611R CxCxC Reducing Tee		1 1/2"			
09	1	2 1/2"	Nibco Wrot 600 Dimpled Stop Coupling CxC		1 1/2"			
10	1	3"x3/4"	Anvil 3000# FS Thread-O-Let		1"			
11	1	3"x1 1/2"	Anvil 3000# FS Thread-O-Let		1 1/2"			
12	10	6	B-Line B2000 ZN Schl 40 Pipe Clamp					
13	4	50"	B-Line 1-5/8 GRN 12GA Bk/Bk 2in Slotted Unistrut			4' - 0 5/8"	2' - 8 5/8"	4' - 6"
14	1	50"	B-Line 1-5/8 GRN 12GA Bk/Bk 2in Slotted Unistrut			2' - 8 5/8"	2' - 8 5/8"	4' - 6"

12 5 6 5/8" B-LINE #2020

15 5 5 5/8" B-LINE #2066


CONNECT TO HP-L07-006

CONNECT TO HP-L07-057



1 ISOMETRIC

SCALE:



2 TOP VIEW

SCALE: 1/2" = 1'-0"

A1	A3	B1	B3
A2	A4	B2	B4


JOB: 210140 - WASH U NRB

TICKET: HP-L07-005

Drawn By: Author

DATE: 11/17/21

DATE REQ:



1233 N. Price Rd.
St. Louis, Mo 63132-2303
314-997-6600 phone