



BIM 360//WUSM NRBWUSM\_RB\_SPOOLING MASTER.rvt  
8/30/2021 12:29:40 PM




2 AS-L03-107 - ISOMETRIC  
AS-L03-107 SCALE:



1 AS-L03-107  
AS-L03-107 SCALE: 1/2" = 1'-0"

A1	A3	B1	B3
A2	A4	B2	B4



1233 N. Price Rd.  
St. Louis, Mo 63132-2303  
314-997-6600 phone

JOB: WASH U NRB


TICKET: AS-L03-107

Drawn By: Author


DATE: 08/30/21 DATE REQ:

BIM 360/WUSM NRBWUSM RB\_PUF.rvt  
8/30/2021 12:33:29 PM

Mark	Qty	Size	Description	Length	Strut Width	Rod 1	Rod 2	Insulation
01	1	14"	B-Line 1-5/8 GRN 12GA 2in Slotted Unistrut		1' - 6"	5' - 0"	5' - 0"	
02	3	0.75"	B-Line BVT Series Vibra-Clamp Strut-Mnt Tube - ZN		0"	0"	0"	




1 ISOMETRIC  
SCALE:



2 TOP VIEW  
SCALE: 3/4" = 1'-0"

A1	A3	B1	B3
A2	A4	B2	B4


JOB:	WASH U NRB
TICKET:	PUHGR-L03-107
Drawn By: Author	
DATE: 08/18/21	DATE REQ:



1233 N. Price Rd.  
St. Louis, Mo 63132-2303  
314-997-6600 phone

BIM 360://WUSM NRB\\WUSM\_RB\_PUF.rvt  
8/30/2021 12:54:55 PM


Mark	Qty	Size	Description	Length	Strut Width	Rod 1	Rod 2	Insulation
01	1	3/4"	Cerro Type L Hard Copper - CFOS	4'-8 5/16"				
02	1	3/4"	Nibco 607-CB CFOS Wrot 90 Elbow					
03	1	3/4"	Nibco 600-DS-CB CFOS Wrot Copper Coupling Staked Stop					



1

ISOMETRIC

SCALE:




2

TOP VIEW

SCALE: 3/4" = 1'-0"

A1	A3	B1	B3
A2	A4	B2	B4


JOB:	WASH U NRB
TICKET:	CO4-L03-107
Drawn By: Author	
DATE: 08/18/21	DATE REQ:




1233 N. Price Rd.  
St. Louis, Mo 63132-2303  
314-997-6600 phone

BIM 360//WUSM NRBWUSM RB\_PUF.rvt  
8/30/2021 12:36:04 PM

Mark	Qty	Description	Length	Strut Width	Rod 1	Rod 2	Insulation	Strut Width
01	1	Cerro Type L Hard Copper - CFOS	5'-10 7/8"					
02	1	Cerro Type L Hard Copper - CFOS	0'-4 5/16"					
03	1	Cerro Type L Hard Copper - CFOS	0'-3"					
04	1	Cerro Type L Hard Copper - CFOS	9'-1 7/8"					
05	1	Cerro Type L Hard Copper - CFOS	0'-1 1/8"					
06	2	Nibco 611-CB CFOS Wrot Copper Tee						
07	1	Nibco 607-CB CFOS Wrot 90 Elbow						
08	3	Nibco 600-DS-CB CFOS Wrot Copper Coupling Staked Stop						
09	4	Generic Silfos Brazed Joint						
10	1	Beacon Medaes SSB-820-10 Brz 3pc Dual FP Shut-Off wLk Lvr Valve						




1 ISOMETRIC  
SCALE:



2 TOP VIEW  
SCALE: 3/4" = 1'-0"

A1	A3	B1	B3
A2	A4	B2	B4


JOB: WASH U NRB  
TICKET: LA-L03-107  
Drawn By: Author  
DATE: 08/18/21



1233 N. Price Rd.  
St. Louis, Mo 63132-2303  
314-997-6600 phone

BIM 360://WUSM NRBWUSM RB PJF.rvt  
8/30/2021 12:40:20 PM

Mark	Qty	Size	Description	Length	Strut Width	Rod 1	Rod 2	Insulation
01	1	3/4"	Cerro Type L Hard Copper - CFOS	5'-11 7/8"				
02	1	3/4"	Cerro Type L Hard Copper - CFOS	3'-11"				
03	1	3/4"	Cerro Type L Hard Copper - CFOS	0'-2 1/4"				
04	1	3/4"	Cerro Type L Hard Copper - CFOS	9'-3 1/8"				
05	1	3/4"	Cerro Type L Hard Copper - CFOS	3/8"				
06	1	3/4"	Nibco 611-CB CFOS Wrot Copper Tee					
07	2	3/4"	Nibco 607-CB CFOS Wrot 90 Elbow					
08	3	3/4"	Nibco 600-DS-CB CFOS Wrot Copper Coupling Staked Stop					
09	1	3/4"	Beacon Medaes SSB-820-10 Brz 3pc Dual FP Shut-Off wLk Lvr Valve					




1 ISOMETRIC  
SCALE:



2 TOP VIEW  
SCALE: 1/2" = 1'-0"

A1	A3	B1	B3
A2	A4	B2	B4

JOB:	WASH U NRB
TICKET:	LVAC-L03-107
Drawn By: Author	
DATE: 08/18/21	DATE REQ:



1233 N. Price Rd.  
St. Louis, Mo 63132-2303  
314-997-6600 phone