



BIM 360://WUSM NRBWUSM_RB_HPF.rvt
10/20/2021 11:31:17 AM




3D Ortho



Elevation Top
1" = 1'-0"


Mark	Qty	Description	Size	Length	Insulation
01	1	Chicago Area Sch 40 SA-53B CS ERW Pipe PE	3"	0'-8 3/8"	1"
02	2	Chicago Area Sch 40 SA-53B CS ERW Pipe PE	3"	0'-5 3/16"	1"
03	1	Chicago Area Sch 40 SA-53B CS ERW Pipe PE	3"	0'-4"	1"
04	1	Chicago Area Sch 40 SA-53B CS ERW Pipe PE	3"	2'-9 1/2"	1"
05	1	Chicago Area Sch 40 SA-53B CS ERW Pipe PE	3"	1'-5 7/8"	1"
06	2	Chicago Area Sch 40 SA-53B CS ERW Pipe PE	3"	1'-2 15/16"	1"
07	2	Chicago Area Sch 40 SA-53B CS ERW Pipe PE	3"	1'-0 13/16"	1"
08	1	Anvil Std SA-53B CS Smls Pipe NIP x Close	3/4"	0'-1 3/8"	1"
09	2	VIC-300 MASTERSEAL BUTTERFLY VALVE BARE	3"		0"
10	2	Weldbend Std Wt SA234 WPB CS BW TEE	3"		1"
11	1	Weldbend Std Wt SA234 WPB CS BW LR 90 Deg Ell	3"		1"
12	1	Weldbend Std Wt SA234 WPB CS BW Cap	3"		1"
13	2	Weldbend Std Wt SA234 WPB CS BW 45 Deg Ell	3"		1"
14	6	Victaulic Style 177 EHP QuickVic Flexible Coupling	3"		1"
15	1	Apollo 77C-140 Brz 2pc FP SS-Vntd-B&S Ball Valve Thd	3/4"		1"
16	5	Anvil 3000# FS Thread-O-Let	3"x3/4"		1"



Elevation Back
1" = 1'-0"

A1	A3	B1	B3
A2	A4	B2	B4

JOB: WASH U NRB
TICKET: AS-L02-219
Drawn By: Author
DATE: 10/19/21
DATE REQ:



1233 N. Price Rd.
St. Louis, Mo 63132-2303
314-997-6600 phone