



Murphy-PFFS-SPOOL-BOM							
Mark	Qty	Description	End 1	End 2	Lft	LDec	Size
13	1	No.647 TT Dielectric Transition Fitting	MPT	MPT	4"	4.000	2
1	1	150lb RF Sch 40 Bore SA105 CS WN Flg					14
4	1	Style W77 Rigid Coupling					14
8	3	Style W77 Rigid Coupling					14
2	2	Std Wt SA234 WPB CS BW LR 90 Deg El					14
6	1	Std Wt SA234 WPB CS BW 45 Deg El					14
10	1	3000# FS Thread-O-Let			1 1/2"	1.500	2x14
7	3	3000# FS Thread-O-Let			1 1/16"	1.063	3/4x14
3	1	Std Wt SA-53B CS ERW Pipe PE	BEV	BEV	0 15/16"	0.925	14
5	1	Std Wt SA-53B CS ERW Pipe PE	Grooved End	BEV	6"	6.000	14
12	1	Std Wt SA-53B CS ERW Pipe PE	Grooved Pipe End	BEV	1'-2"	14.022	14
9	2	Std Wt SA-53B CS ERW Pipe PE	Grooved End	Grooved End	1'-0"	12.000	14
11	1	Std Wt SA-53B CS ERW Pipe PE	BEV	Grooved End	8"	8.000	14

MURPHY
SINCE 1907

CONSTRUCTORS • ENGINEERS MECHANICAL • INDUSTRIAL

1233 N. Price Rd.
St. Louis, MO 63132-2303
314-997-6600 phone
BIMCAD@murphy-stl.com

DRN JMM	5/12/2021	WUSM RESEARCH BUILDING				QA/QC ACCEPT				FLANGE WEIGHT/ORIENTATION					
		NRB CUP								FITTING ORIENTATION					
		LVLO2 SPOOLS								BOLTS/CPLG'S/TH'D TIGHT					
		CH#5 TWR								SPOOL IDENTIFICATION					
CHK															
APP															
JOB NO.	210140	SERVICE NAME													
REF.DWG.															
DRAWING NO./TRACKING NO.	210140-A-UPL2-20-11	QTY.	1	SHT/NO	1 of 1	REV	0								
		DATE		DESCRIPTION		REV		DATE		DRN		CHK		APP	