



Murphy-PFFS-SPOOL-BOM

Mark	Qty	Description	End 1	End 2	Lft	LDec	Size
6	4	Std Wt SA234 WPB CS BW RED TEE					24x12
5	1	Sch 40 SA-53B CS ERW Pipe Saddle			1'-6"	18.000	24x12
7	4	150lb RF Sch 40 Bore SA105 CS WN Flg					12
3	1	Std Wt SA234 WPB CS BW Cap					12
1	1	Std Wt SA234 WPB CS BW Cap					24
8	4	Std Wt SA234 WPB CS BW LR 90 Deg El					12
4	1	3000# FS Thread-O-Let			1 1/16"	1.063	3/4x12
2	1	Std Wt SA-53B CS SMLS Pipe PE	BEV	BEV	1'-5 7/8"	17.875	24
9	3	Std Wt SA-53B CS SMLS Pipe PE	BEV	BEV	3'-7 3/4"	43.750	24

MURPHY
SINCE 1907

CONSTRUCTORS • ENGINEERS MECHANICAL • INDUSTRIAL

1233 N. Price Rd.
St. Louis, MO 63132-2303
314-997-6600 phone
BIMCAD@murphy-stl.com

<input type="checkbox"/> FLANGE WEIGHT/ORIENTATION				
<input type="checkbox"/> FITTING ORIENTATION				
<input type="checkbox"/> BOLTS/CPLG'S/TH'D TIGHT				
<input type="checkbox"/> SPOOL IDENTIFICATION				

QA/QC ACCEPT				
SPEC.	ASME	X-RAY	HYDRO TEST	COMMENTS
NA	NA	NA	NA	MURPHY WPS#
0				
REV	DATE	DESCRIPTION		DRN
				CHK
				APP

DRN	JMM	3/22/2021	WUSM RESEARCH BUILDING		
CHK			NRB		
APP					
JOB NO.	210140		SERVICE NAME	LPS	
REF.DWG.			QTY.	SHT/NO	REV
DRAWING NO./TRACKING NO.		1	1 OF 1	0	0
210140-A-UPL1-9					