



Murphy-PFFS-SPOOL-BOM							
Mark	Qty	Description	End 1	End 2	Lft	LDec	Size
9	1	Std Wt SA234 WPB CS BW CONC RED					14x10
8	1	Style W07 Rigid Coupling					14
12	1	77C-140 Brz 2pc FP SS-Vntd-B&S Ball Valve Thd					3/4
13	1	No.647 TT Dielectric Transition Fitting					3/4
2	1	Std Wt SA234 WPB CS BW LR 90 Deg El					10
6	1	Std Wt SA234 WPB CS BW 45 Deg El					10
1	1	3000# FS Thread-O-Let			1 5/16"	1.313	1x10
14	1	3000# FS Thread-O-Let			1 1/16"	1.063	3/4x10
5	1	Sch 40 SA-53B CS ERW Pipe PE	BEV	BEV	1'-0 7/16"	12.441	10
11	1	Sch 40 SA-53B CS ERW Pipe PE	BEV	BEV	2'-0"	24.000	10
7	1	Std Wt SA-53B CS ERW Pipe PE	Grooved End	BEV	6"	6.000	14
4	1	Sch 40 SA-53B CS ERW Pipe PE	BEV	Grooved End	6"	6.000	10

MURPHY
CONSTRUCTORS • ENGINEERS MECHANICAL • INDUSTRIAL

1233 N. Price Rd.
St. Louis, MO 63132-2303
314-997-6600 phone
BIMCAD@murphy-stl.com

<input type="checkbox"/> FLANGE WEIGHT/ORIENTATION	<input type="checkbox"/> FITTING ORIENTATION	<input type="checkbox"/> BOLTS/CPLG'S/TH'D TIGHT	<input type="checkbox"/> SPOOL IDENTIFICATION
QA/QC ACCEPT			
SPEC.	ASME	X-RAY	HYDRO TEST
NA	NA	NA	NA
0			
REV	DATE	DESCRIPTION	DRN
			CHK
			APP

DRN	JMM	5/12/2021	WUSM RESEARCH BUILDING		
CHK			NRB CUP		
APP			LVLO2 SPOOLS		
JOB NO.	210140		SERVICE NAME	CH#4	CHWR
REF.DWG.					
DRAWING NO./TRACKING NO.	210140-A-UPL2-19-06	QTY.	1	SHT/NO	1 of 1
		REV	0		